

- 3.19 Water treatment apparatus installed at the Customer Premises which utilises chemicals for water disinfection, or treatment processes that may alter water quality characteristics prior to metering, shall not be installed. Where further treatment is required for certain applications, the Responsible Person must consult the Distribution Company or the authority concerned.
- 3.20 Central filtration systems or any other water treatment equipment installed, particularly in multi-tenanted and commercial buildings, must be maintained and operated according to the manufacturer's recommendations. By-pass arrangements shall be considered in case of system failures.
- 3.21 Almost all water supplied by the Distribution Companies in the Emirate of Abu Dhabi is desalinated water, therefore water treatment equipment specified must be considered following a technical evaluation by the Responsible Person. The Responsible Person may wish to seek information and data on the water quality supplied to the area of residence from the Distribution Company (e.g. Total Dissolved Solids, pH, Chlorine and Hardness... etc.) to verify whether additional treatment is required.