

Damage Performance Objective under (E2) level earthquake, and *Collapse Prevention / Extensive Damage Performance Objective* under (E3) level earthquake.

1.3.4.2 – The performance objectives of tall buildings in *Special Occupancy Class* (health, education, public administration buildings, etc.) are identified as *Immediate Occupancy / Minimum Damage Performance Objective* under (E2) level earthquake, and *Life Safety / Controlled Damage Performance Objective* under (E3) level earthquake.

1.3.4.3 – Upon the requirement of the Owner or the relevant State Authority, higher performance objectives, such as those given in **13.4.2**, may be identified for tall buildings in *Normal Occupancy Class* (residence, hotel, office building, etc.) instead of those defined in **1.3.4.1**.

Table 1.2. Minimum performance objectives identified for tall buildings under various earthquake levels

Building Occupancy Class	(E1) Earthquake Level	(E2) Earthquake Level	(E3) Earthquake Level
Normal occupancy class: Residence, hotel, office building, etc.	IO / MD	LS / CD	CP / ED
Special occupancy class: Health, education, public admin. buildings, etc.	—	IO / MD	LS / CD