

1. Water storage tanks

Water demand and sizing criteria

- 1.1 The demand criteria in Table 1.1 should only be used as a guide when calculating the size of storage tanks. They may also be used by the Distribution Company for sizing new water service connections and fittings. However, in line with Distribution Company demand management practices, which ensure that 'reasonable demand' is constantly monitored, consumption rates may be modified. Please refer to the relevant Distribution Company for updated rates.
- 1.2 The figures in Table 1.1 are estimates of daily demand rate in both litres and imperial gallons for various types of residential and commercial Premises. Sizing of water connections to agricultural, industrial and other high-consumption Customers shall be determined by the Distribution Company's supply and demand management policies.
- 1.3 The provision of Ground Storage Tanks at Customer Premises (particularly in buildings not higher than 10 metres) shall be considered following consultation with the relevant Distribution Company to verify the availability of Adequate Network Pressure as prescribed in the Water Supply Regulations.