

- D. Visual inspection of large diameter pipe is recommended when practical. If not practical then other means of ensuring no crushed, broken, separated joints or other obstructions exist shall be used.
- E. Field inspection and testing of other works and equipment shall be done as per requirements outlined in other Sections

25.3.8 Protection

- A. Protect finished Work under provisions of other Sections.
- B. Protect pipe and aggregate cover from damage or displacement until backfilling operation is in progress.

END OF SECTION

QC
Copy