

- F. Cabinet Mounting Hardware: Appropriate to cabinet.
- G. Form cabinet enclosure with right angle inside corners and seams. Form perimeter trim.
- H. Pre-drill for anchors.
- I. Hinge doors for 180 degree opening with two butt or continuous piano hinge. Provide roller type catch.
- J. Weld, fill, and grind components smooth.
- K. Glaze doors with resilient channel gasket glazing.
- L. Finishing Cabinet Exterior Trim and Door: Primed for field paint finish and Red baked enamel, colour as selected.
- M. Finishing Cabinet Interior: enamel.

4.2.3 Accessories

- A. Not Used
- B. Extinguisher Brackets: Formed steel, galvanised enamel finish.
- C. Not Used
- D. Cabinet Signage or Graphic Identification

4.3 Part 3 Execution

4.3.1 Examination

- A. Section 01039 - Coordination and Meetings: Verification of existing conditions before starting work.
- B. Verify rough openings for cabinet are correctly sized and located.

4.3.2 Installation

- A. Install in accordance with manufacturer's instructions.
- B. Install cabinets plumb and level in wall openings, 83 mm from finished floor to inside bottom of cabinet.
- C. Secure rigidly in place.
- D. Place extinguishers and accessories in cabinets or on wall brackets.
- E. Position cabinet signage.