

## Floor surfaces

Facility/Building .....

Space/Floor .....

Sheet Number .....

YES

N/A

NON

Observations

<b>Slip resistance (PTV) comply:</b> - Level and inclined with $\leq 5\%$ dry areas indoor - Between 15 and 35 <input type="checkbox"/> - Inclined $< 5\%$ dry areas indoor $\geq 35$ <input type="checkbox"/> - Level and inclined with $\leq 5\%$ wet areas and outdoor - Between 35 and 45 <input type="checkbox"/> - Inclined $< 5\%$ wet areas and outdoor $\geq 45$ <input type="checkbox"/> - Street pavement, swimming pools and showers $\geq 45$ <input type="checkbox"/>				
<b>Ground pavement without loose elements</b>				
<b>Rugs and carpets are firmly fixed and do not increase the strength required to roll over a ceramic pavement by <math>\geq 25\%</math></b>				
<b>Without rounded edges and excessive joints</b>				
<b>Not producing glare</b>				
<b>With reflectance contrast of at least 30 points LRV</b>				
<b>Lighting in floor not produces glare and excessive heat</b>				