

- D. Chrome/Nickel Plating: ASTM B456, Type SC 2 polished finish.
- E. Stainless Steel: No. 4 satin lustre or polished finish.
- F. Black paint components where contact is made with building finishes preventing electrolysis.

5.3 Part 3 Execution

5.3.1 Examination

- A. Verify site conditions under provisions of Section 01039.
- B. Verify that site conditions are ready to receive work and dimensions are as indicated on shop drawings or as instructed by the manufacturer.
- C. Verify exact location of accessories for installation.

5.3.2 Preparation

- A. Deliver inserts and rough-in frames to site for timely installation.
- B. Provide templates and rough-in measurements as required.

5.3.3 Installation

- A. Install accessories in accordance with manufacturers' instructions.
- B. Install plumb and level, securely and rigidly anchored to substrate.

5.3.4 Schedule

	ITEM	FINISH
A.	Toilet Tissue Dispenser	Stainless Steel
B.	Flexible Hose	Stainless Steel
C.	Robe Hook	Stainless Steel
D.	Soap Dispenser:	Stainless Steel
E.	Shower Curtain rails (25mm tube)	Stainless Steel
F.	Shower Curtain: Plain White Plastic complete with eyelets and hooks	
G	Towel rails: 25mm diameter tube chrome plated, plug and screw to wall	
H.	Mirrors: Copper backed float glass, 6mm thick to the size shown on the Drawings, pre-drilled and fixed with chrome plated dome head screws. Distance washers shall be fixed behind mirror fixing points.	