

Accessible path of travel				
Facility/Building				Sheet Number
Space/Floor				
	YES	N/A	NON	Observations
Enough width - more than 2000 mm and with no obstacle reducing it to less than 1200 mm.				
Linear and continued				
Intersections clearly visible with signs or lights				
Gradient $\leq 5\%$				
Clear headroom ≥ 2200 mm				
Absence of uneven surfaces - irregularities ≤ 5 mm				
Absence of protruding objects - No object protruding into the pedestrian path more than 100 mm and furniture comply detection cone rule.				
Illumination level ≥ 10 lux				
No drain grids on accessible path or accessible crossings				
Free of obstacles and located between the building's façade and the furniture zone				
Parking entrance do not modify the slope or width of the accessible path				
Curb height between 100 mm and 150 mm				
Cross slope gradient $\leq 2\%$				