

COMPLIANCE DOCUMENTATION

Table 401.03(2): Documents Required

Project Stages	Submittal Documents
Design Permit Application	1. Mechanical drawings, marked-up to clearly show distances between outdoor air intake points including doors & openable windows and exhaust air discharge outlet or other discharge points.
Construction Completion Application	1. Final approved layout, marked-up to clearly show distances between outdoor air intake points including doors & openable windows and exhaust air or other discharge points.
After Completion	NA

REFERENCES AND ADDITIONAL INFORMATION

American Society of Heating, Refrigerating and Air-Conditioning Engineers. (2016). ASHRAE standard 62.1: Ventilation for Acceptable Indoor Air Quality, www.ashrae.org.

American Society of Heating, Refrigerating and Air-Conditioning Engineers. (2016). ASHRAE standard 62.2: Ventilation for Acceptable Indoor Air Quality in Low-Rise Residential, www.ashrae.org.

American Society of Heating, Refrigerating and Air-Conditioning Engineers. (2015). ASHRAE Handbook—HVAC Applications, www.ashrae.org.