

The upper band shall be affixed at a height between 1400 mm and 1600 mm and the lower band affixed at a height between 850 mm and 1000 mm above the floor.



Figure 36. Glass marks

It is not necessary to mark the glass surfaces with contrasted bands in the following cases:

1. In glass surfaces of less than 500 mm in width.
2. The highest point of the glass surface is less than 850 mm.
3. If it has other opaque elements between 850 mm and 1700 mm occupying its entire width.
4. If it has other types of marks (logo, artistic illustrations, etc.) that occupy 50% of the area between 850 mm and 1700 mm without empty spaces bigger than 500 mm wide.
5. Glass surfaces with fixed elements in front of it that block the entire approaching space.

## 5.17. Accessible toilets

All public facilities and new public mobile or fixed toilets installed in parks, gardens, squares, streets, exhibitions, fairs, concerts, and in outdoor public spaces and buildings for public use shall have at least one accessible toilet for each gender and in every bank