

- E. If the Client has appointed an independent third party inspection then their report shall be submitted to and approved by the Engineer, with a copy to the pipe Manufacturer, prior to any inspected materials being installed on site.
- F. The Engineer may reject any item that does not successfully pass the required tests or fully comply with the requirements of this specification.
- G. When a pipe or fitting is rejected, the items manufactured immediately before or after shall be carefully examined. If further defects are found, the entire pipe batch will be rejected.

QCC-V  
Copy