

The number of accessible toilets shall follow the table 7.

NUMBER OF ACCESSIBLE TOILETS	
Use of the Building, establishment or area	Minimum Number of Toilets
Any public use	1 Accessible toilets for each gender should be provided in every floor being at least 10% of the total number of toilets in every block or 1 independent accessible toilet for both genders
	1 accessible toilet within a 150 meters distance from any part of the building

Table 7. Number of Accessible Toilets

The following table indicates the minimum dimensional parameters required for accessible toilets:

Minimum dimensions for accessible toilets	
<b>Dimensions of circulation spaces</b>	
Corridor widths in toilets, showers, lockers spaces, etc.	1200 mm
Manoeuvring turning space diameter	1500 mm
<b>Accessible toilets and cubicles conditions</b>	
Manoeuvring space diameter between 0 and 700 mm height free of obstacles	1500 mm
Lateral interaction space	On both sides

Table 8. Minimum dimensional parameters for accessible toilets