

## Appendix D

Code, NFPA 58, *Liquefied Petroleum Gas Code* or equivalent International Standard(s) approved by the Authority Having Jurisdiction. Fuel oil supply systems shall comply with the applicable provisions of NFPA 31, *Standard for the Installation of Oil-Burning Equipment* or equivalent International Standard(s) approved by the Authority Having Jurisdiction. [NFPA 501A:4.5]

### **D 40.0 Community Building Fuel Supply Systems in Manufactured Home Communities.**

**D 40.1 Fuel Gas Piping and Equipment Installations.** Fuel gas piping and equipment installed within a permanent building in a M/H community shall comply with nationally recognized appliance and fuel gas piping codes and standards adopted by the Authority Having Jurisdiction. Where the state or other political subdivision does not assume jurisdiction, such fuel gas piping and equipment installations shall be designed and installed in accordance with the appropriate provisions of NFPA 54, *National Fuel Gas Code*, NFPA 58, *Liquefied Petroleum Gas Code* or equivalent International Standard(s) approved by the Authority Having Jurisdiction. [NFPA 501A:4.6.1]

**D 40.2 Oil Supply Systems in M/H Communities.** Oil-burning equipment and installation within a M/H community shall be designed and constructed in accordance with the applicable codes and standards adopted by the Authority Having Jurisdiction. Where the state or other political subdivision does not assume jurisdiction, such installation shall be designed and constructed in accordance with the applicable provisions of NFPA 31, *Standard for the Installation of Oil-Burning Equipment* or equivalent International Standard(s) approved by the Authority Having Jurisdiction. [NFPA 501A:4.6.2]

**D 40.3 Oil-Burning Equipment and Installation.** Oil-burning equipment and installation within a building constructed in a M/H community in accordance with the Building Code shall comply with nationally recognized codes and standards adopted by the Authority Having Jurisdiction. Where the state or other political subdivision does not assume jurisdiction, such oil-burning equipment and installation shall be designed and installed in accordance with the appropriate provisions of NFPA 31, *Standard for the Installation of Oil-Burning Equipment* or equivalent International Standard(s) approved by the Authority Having Jurisdiction. [NFPA 501A:4.6.3]

**D 40.4 Inspections and Tests.** Inspections and tests for fuel gas piping shall be made in accordance with Chapter 12 of this code.

## UNIFORM PLUMBING CODE OF ABU DHABI: AN ENVIRONMENTAL GUIDE FOR WATER SUPPLY AND SANITATION

### Part E

#### **Recreational Vehicle Parks Definitions and General Requirements.**

##### **D 41.0 Recreational Vehicle (RV).**

A vehicular-type unit primarily designed as temporary living quarters for recreational, camping, travel, or seasonal use, that either has its own motive power, or is mounted on or towed by another vehicle. The basic entities are camping trailer, fifth-wheel trailer, motor home, park trailer, travel trailer, and truck camper.

##### **D 42.0 Recreational Vehicle Park.**

A lot of land upon which two or more recreational vehicle sites are located, established, or maintained for occupancy by recreational vehicles of the general public as temporary living quarters for recreation or vacation purpose.

##### **D 43.0 Recreational Vehicle Site.**

Within a recreational vehicle park, a lot of ground intended for the accommodation of a recreational vehicle, a tent, or other individual camping unit on a temporary basis.

##### **D 44.0 General.**

All plumbing shall be installed in accordance with the plumbing codes of the Authority Having Jurisdiction and with this appendix.

### Part F

#### **Recreational Vehicle Park Toilet and Shower Facilities.**

##### **D 45.0 Water Closets.**

Water Closets and urinals shall be provided at one or more locations in every recreational vehicle park. They shall be convenient of access and shall be located within a radius equal to 150m (500 ft.) from any recreational vehicle site not provided with an individual sewer connection.

##### **D 46.0 Marking.**

Facilities for males and females shall be appropriately marked.

##### **D 47.0 Minimum Number of Water Closets.**

Not less than one water closet shall be provided for each sex up to the first 25 sites. For each additional 25 sites not provided with sewer connections, an additional water closet shall be provided.