

elevator unless it is supplied with the necessary equipments for the people of peculiar needs

10. Security and safety conditions should be provided for the different groups of the people of peculiar needs.
- b. In the invested building whose total area is more than (50000) square feet, the following should be provided:
 1. Ramps with a slope rate that is not more than (1) to (12) centimeters at sidewalks, outer stairs and the points of different levels wherever it is inside and outside the building.
 2. One of the elevators and the passages should be in the floors, outer movement lanes and in parking lots with sufficient specifications and dimensions to be large enough for the movement of the people of peculiar needs according to the approved standards.
 3. The number for the parking lots which are for the people of peculiar needs should not be less than (1%) of the total number for parking lots where a part of it is considered a complete parking lot with a limit superior (5) parking lots.
 4. The measurements for the parking lots should be according to the standards related to the people of peculiar needs. The parking lots should be close to the elevators or to the main entrances of the building.
 5. Instructions that are related to the parking lots of the people of peculiar needs should be put wherever it is needed according to what the approved standards define.
 6. The movement lanes for the people of peculiar needs should be direct and their measurements should correspond to the approved standards and they do not have any obstacles.
- c. In hotels that are classified from the group of three stars or more, the following services should be provided as a limit inferior for the people of peculiar needs:
 1. One hotel room in the first floor if the number of the hotel rooms and suites is less than (100) and two rooms if it is more than (100)
 2. This room should be completely equipped according to the international standards that are related to the people of peculiar needs concerning the room dimensions, the door, the spaces surrounding the bed, the medial rotation places with a diameter not less than (1.5) meters, automatic opening window and designing a desk, a cupboard, electric keys, an emergency alarm bell and a chair.
 3. The room should be supplied with a bathroom according to the approved international standards related to the people of peculiar needs concerning the bathroom seat, bathing tub, the sink, the surrounding spaces, cupboards, mirrors, the quality of the floor, the doors dimensions and their movements, the location of the complement elements in the bath and the locations of the handles of support and help.