

- xi. Detailed information on coatings.
- xii. Certificate of compliance of the used non-metallic materials with requirements of the BS6920.

19.1.4.2 Method Statements

- A. The Contractor shall submit method statements to the Engineer for approval 4 weeks in advance of commencing the site activity in accordance with Section 01300 of the specification. These shall comprise but not necessarily be limited to:
 - i. Procedures for handling, storage and installation of pipes including cleaning and repair.
 - ii. Hydrostatic testing procedures.

19.1.4.3 Working Drawings.

- A. The Contractor shall submit drawings to the Engineer for approval in advance of commencing the site activity in accordance with Section 01300 of the specification. These shall comprise but not necessarily be limited to:
 - i. Drawings of the pipes, fittings, joints, pipe specials and the assembly thereof.

19.1.5 Quality Control

- A. Prior to dispatch of any product and/or material from source the Contractor shall notify the Engineer in writing in sufficient time to allow the Engineer the opportunity to inspect and test the product and/or material prior to delivery in accordance with Section 01400 of the specification.
- B. Products and materials shall be from a manufacturer/supplier with certificate of conformity to BS EN 598 latest addition or type test certificate for tests carried out on similar pipes and fittings. Certificate shall be issued by an approved recognized third party accredited agency. In addition, manufacturer shall be approved to:
 - ISO 9001:20008
 - ISO 14001:20004
 - OHSAS 18001:2007.