




SECTION A-A



PLAN AT COVER LEVEL



SECTION B-B



COVER SLAB DETAIL FOR CARRIAGEWAY & PARKING AREAS

NOTES:

- THESE DETAILS REPRESENT A MINIMUM REQUIREMENT AND MAY BE VARIED, SUBJECT TO APPROVAL, TO SUIT PROJECT REQUIREMENTS. THEY ARE EXPECTED TO BE INCORPORATED AS TYPICAL DETAILS WHICH SHALL BE CHECKED AND APPROVED AS PART OF THE PROJECT DRAWING SET.
- ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
- THE MANHOLES AND CHAMBERS ARE DESIGNED USING FULL GROUND WATER LEVEL CONDITION WITH 1.1 FACTOR OF SAFETY FOR FLOATATION AND BEARING PRESSURE NOT EXCEEDING 200kpa AT FORMATION LEVEL.
- DEWATERING OPERATIONS SHALL BE PROVIDED DURING CONSTRUCTION AND MAY ONLY BE TERMINATED AFTER ROOF SLAB HAS BEEN CAST.

LEGEND

	REINFORCED CONCRETE
	SOIL COMPACTED TO 95% MDD
	PLAIN CONCRETE
FGL	FINAL GROUND LEVEL
FL	FINAL ASPHALT / INTERLOCKED TILE LEVEL
DIA	DIAMETER
FA	FLANGE ADAPTOR
FC	FLEXIBLE COUPLING
SC	STEPPED COUPLING
IPF	INTEGRAL PUDDLE FLANGE
ST	SCREED THICKNESS

REFERENCE DRAWINGS AND DOCUMENTS

STANDARD DRAWING - TANKING DETAILS	- 801
STANDARD DRAWING - CONSTRUCTION AND MOVEMENT JOINT	- 1001
STANDARD DRAWING - MISCELLANEOUS DETAILS FOR MANHOLES	- 207
STANDARD DRAWING - REINFORCEMENT DETAILS	- 1000 (SERIES)
STANDARD DRAWING - STORM WATER MANHOLE FRAME AND COVER DETAILS	- 213

No.	REVISIONS	APP'D	DATE
-----	-----------	-------	------

CLIENT

TITLE
STANDARD DRAWINGS
STORM WATER WORKS

DRAWING TITLE
STANDARD DRAWING WEIR
DISCHARGE CHAMBER FOR
STORM WATER PUMPING MAIN

DRAWN	-	SCALE	1 : 50
CHECKED	-	DATE	-
APPROVED	-	SIZE	A1
PROJECT No.	-	DWG. No.	402