

The quantity and location of the entry boxes will depend on the main and redundant route from the main telecom room to the Operator networks. Entry boxes must be included wherever the duct system has right-angle or sharp bends where there are other factors that might restrict cable pulling.

The following specifications must be followed:

- a)** Constructed of reinforced concrete;
- b)** Fitted with a ductile iron frame and cover;
- c)** Minimum load rating 400 kN;
- d)** Cover to be marked 'Telecoms';
- e)** An earth rod must be provided with a resistance of less than 5 ohms.

All Lead-In ducts corridors shall follow the local authorities regulations and to be approved during NOC stage.