

B. Current Transformers:

Sr. No.	Description	
1.	Rated Secondary Current	5A
2.	Maximum primary voltage	600 V
3.	Rated Frequency	50 Hz
4.	Rated primary Current (only one is applicable)	160A, 200A, 300A, 400A, 800A, 1600A or 2400A
5.	Rated burden	5 VA
6.	No. of Phases	1
7.	<u>Accuracy Class</u> <u>CT Application</u> CT metering on LV system	<u>System Rating</u> > 125A 0.2S
8.	Medium of installation	Air
9.	Size of Busbars (Primary) <u>Rated Primary Current</u> a) 160A, 200A, 300A b) 400A c) 600A, 800A d) 1200A, 1600A e) 2400A	<u>Busbar Size</u> 20 mm x 10mm 30 mm x 10 mm 50 mm x 10 mm or 2 Nos. x 30mm x 10mm 2 Nos. x 60mm x 10 mm 2 Nos. x 80mm x 10mm