

12.2.9 On-Site Renewable Energy - Outdoor Lighting

For all buildings where the light power density of external lighting exceeds that specified in Regulation 12.2.3, Building Exterior Lighting Power Density, any additional lighting load must be powered entirely through renewable electricity sources such as photovoltaic systems.