

## APPENDIX 8

### SPECIFICATIONS OF DBs

(Refer section 4 of Regulations)

**DB No. :**

<b>I. REFERENCE STANDARDS</b>	BS EN 61439, BS EN 60947, IEC 61439
<b>II. RATING OF INCOMING SUPPLY BREAKER/ISOLATOR+ (+On-load)</b>	40A [ ]      60A [ ]      100A [ ] 125A [ ]      ..... [ ] BREAKER [ ] ISOLATOR [ ]
<b>III. CONSTRUCTION</b>	
1. Mounting	Wall [ ]      Pedestal [ ]      Surface [ ] Recessed [ ]
2. Degree of protection of the enclosure for installation	Indoor-IP41/42 [ ]      Outdoor-IP54/55 [ ] ..... [ ]
3. Painting/Finish (Internal/External)	Stove enamelled [ ]      Epoxy [ ] Polyester [ ]      Galvanized [ ] ..... [ ]
4. Front Cover (+Neoprene)	Hinged [ ]      Bolted [ ]      Panel lock [ ] Gasketted+ [ ]
5. Cable Tray/Conduit entry	Top [ ]      Bottom [ ]      Top & Bottom [ ]
6. Assembly	Factory Assembled [ ]      ..... [ ]
<b>IV. INTERNAL LAYOUT/ARRANGEMENT &amp; FAULT RATING</b>	
1. Segregation of live parts :-  Incoming supply terminals/lugs	Barrier [ ]      Shroud [ ]      Firmly secured [ ] *Separately mounted & Removable by tool [ ]
Bus bar, tap-off connections & terminals (*Separate and independent of each other)	Barrier [ ]      Firmly secured [ ] *Separately mounted & Removable by tool [ ]