

10.U.V. Relays with auto-reset timer	Window A/C [] Split A/C [] Others..... []
V. IDENTIFICATION	
1. Rating of Incoming supply & Outgoing circuit breakers:- (vis-a-vis the rating specified - Refer approved Single Line Diagram/ Distribution Schedules)	Thermal [] Fault [] Discrimination []
Type of circuit breakers :- Incoming Outgoing (C/L-Current Limit)	Isolator [] MCCB [] C/L MCCB [] C/L MCCB [] F/S [] C/L [] For general loads, Type '1'/'L' [] for Motor load, Type '2'/'G'/'.....[]
2. Colour codes for internal, main circuits wiring :- Phase Neutral Earth	Red / Yellow / Blue [] Black [] Green and Yellow []
3. Terminal ferrules for control/auxiliary circuits	Indicating Instruments [] Others..... []
4. Permanent labels, engraved, 'trafolite' or similar	Board Designation [] Controls [] Circuit Designation [] Indications [] Warning Notice/s [] ELCB/U.V. Relay Section []
VI. EARTHING	
1. Rating/size of Earth bus-bar & terminals	Compliance with Regulation Section.5..... [] Adequate, consistent with the min. fault rating specified under IV.4 [] Adequate No. & size to terminate Main & Circuits ECCs []