

## APPENDIX 11

### SPACING OF SUPPORTS FOR TRUNKING, CONDUITS AND CABLES

(Refer section 6 for Regulations)

#### Recommended maximum spacing of Clips, Cleats, Saddles or supports

##### 1. TRUNKING:

Method of installation	Spacing of support in cm	
	Steel	Rigid PVC
Horizontal	150	100
Vertical	180	120

##### 2. CONDUITS:

Method of installation	Spacing of support in cm	
	Steel	Rigid PVC
Horizontal	120	100
Vertical	150	120

##### 3. ARMOURED CABLES:

Method of installation	Spacing of support in cm	
	Overall dia. 2 cm - 4 cm	Overall dia.exceeding 4 cm
Horizontal	35	60
Vertical	60	80