

TABLE K-1 Addenda to ANSI/ASHRAE Standard 62.1-2013

Addendum	Section(s) Affected	Description of Changes*	Approval Dates:
			• Standards Committee • ASHRAE BOD • ANSI
f	Table 5.5.1 Air Intake Minimum Separation Distance; Section 5.5.2 Rain Entrainment; 9. References; F1.1 Application; New Informative Appendix J—Informative Bibliography	In preparation for publication of Standard 62.1-2016, this addendum updates the normative references included in the Standard. This process includes reviewing the references to ensure that their content has not been changed such that they should no longer be referenced and that they are written in normative language. References that are not in normative language are being moved to a new Informative Bibliography. In some cases, the language of the Standard where these documents are referenced needs to be modified. In particular, changes to the notes to Table 5.5.1 are made to avoid referencing non-normative documents and to improve the normative language used.	January 23, 2016 January 27, 2016 (Technology Council) January 28, 2016
g	5.11.2 Finned-Tube Coil Selection for Cleaning	This addendum is from a change proposal submitted from outside the SSPC. The proposer pointed out that the addendum provided an exception which essentially allows coils which are very difficult to clean as long as “instructions for . . . cleaning” are provided. The SSPC agrees that providing instructions does not make cleaning these coils any more feasible, and therefore the exception should be deleted.	January 23, 2016 January 27, 2016 (Technology Council) January 28, 2016
h	3. Definitions; 4.2 Local Air Quality; 4.3 Documentation; 5.4.1 Resistance to Mold Growth; 5.5.2 Rain Entrainment; 5.5.4 Snow Entrainment; 5.7 Combustion Air; 5.9.2 Building Exfiltration; 5.10.2 Drain Outlet; 5.10.4 Pan Size; 5.13.1 Equipment Clearance; 5.14.2 Condensation on Interior Surfaces; 5.16.1 Classification; 5.16.2.1 Air Cleaning; 5.16.2.3 Ancillary Spaces; 5.17.7 Signage; 5.17.8 Reclassification; 6.1 General; 6.1.3 Natural Ventilation; 6.2.1 Outdoor Air Treatment; Table 6.2.2.1 Minimum Ventilation Rates in Breathing Zone; 6.2.2.3 Zone Outdoor Airflow; 6.2.5.1 Primary Outdoor Air Fraction; 6.2.5.3.2 Design System Population; 6.2.6.1 Variable Load Conditions; 6.3.1 Contaminant Sources; 6.3.4 Design Approach; 6.3.5 Combined IAQ Procedures and Ventilation Rate Procedure; 6.4.1.3 Corner Openings; 6.4.3 Control and Accessibility; 6.6 Design Documentation Procedures; 7.2.3 Testing of Drain Pans; 8.4.1.3 Humidifiers; 8.4.1.4 Dehumidification Coils; Table 8.4.1 Minimum Maintenance Activity and Frequency; 8.4.1.8 Outdoor Airflow Verification; 9. References; Normative Appendix A—Multiple-Zone Systems	The changes to the standard in this addendum are for the purpose of complying with ASHRAE’s mandatory language policy for standards. The changes are intended to clarify the requirements and reduce ambiguity in interpretation and enforcement. Many of these changes will change requirements of the standard.	January 23, 2016 January 27, 2016 February 24, 2016
i	3. Definitions; 5.5 Outdoor Air Intakes; Normative Appendix B—Separation of Exhaust Outlets and Outdoor Air Intakes	This addendum changes Appendix F (Separation of Exhaust Outlets and Outdoor Air Intakes) from informative to normative. This addendum is for the purpose of making language in the standard mandatory in compliance with current ASHRAE requirements. The 2016 edition of Standard 62.1 renames Normative Appendix F as Normative Appendix B. Subsequent appendices are renamed accordingly.	January 23, 2016 January 27, 2016 February 24, 2016

* These descriptions may not be complete and are provided for information only.