

On **15 June 2026**, the **Air Handling Unit AHU-12** located in **Building A, Floor 3** unexpectedly shut down during normal operation. Upon inspection, technicians found that the **chilled water valve** had become mechanically jammed due to **severe corrosion** around the valve stem. This caused insufficient cooling to the office area, resulting in occupant complaints about high indoor temperatures. The valve was replaced, the system was restarted successfully, and a follow-up inspection has been scheduled for next week. Due to the impact on multiple occupants, the issue was classified as **High Severity**.