

UNRECOVERED ENERGY EQUIVALENT

122 homes or 313 EVs

(1.26kW/hr) (powered continuously) (.35kW/hr)

PEAK DEMAND

1532.8 kW

(per this period)

HOURLY DATA UoS

Raw Energy Data

RECOVERABLE ENERGY

148.3 kVA

(unconsumed power)

APPARENT

964.7 kVA

694,595.5 kVA /mo

ACTIVE

816.5 kW

587,854.7 kW /mo

REACTIVE

513.9 kVAR

756.9 kVAR MAX

RECOVERABLE CO2e

484.8 MT /YR

122.0 LBS /hr

VOLTAGE

474.3 VOLTS

503.6 MAX 0.0 MIN

AMPERAGE

1174.3 AMPS

2126.8 AMPS MAX

HARMONICS

25.0 % iTHD

121.0 % iTHD MAX

XFMR CAPACITY

70.3 % CAP

1713.1 kVA MAX

POWER FACTOR

84.6 % PF

92.6% MAX 0.0% MIN

T15 Voltage Drops - July 2025

8 or more potential inductive devices are signaling stall characteristics,

Group ID	Drop Count	Voltage Range	Amp Range	Delta V	Est. Stall	Days
G1	11	414.2–417.8V	1155.7–1796.8A	65.8V	210.5A	11
G2	6	436.0–441.7V	172.5–782.1A	44.0V	39.3A	6
G3	5	426.3–433.5V	236.5–1673.2A	53.7V	105.4A	5
G4	3	446.2–450.9V	261.1–1682.2A	33.8V	59.6A	3
G5	2	422.6–422.7V	1630.8–1653.9A	57.4V	196.6A	2
G6	1	388.9V	1188.5–1188.5A	91.1V	225.6A	1
G7	1	402.2V	1618.8–1618.8A	77.8V	262.5A	1
G8	1	409.0V	1547.1–1547.1A	71.0V	228.9A	1

