



CITY OF
AmesTM
INSPECTIONS

APPLIANCE CERTIFICATION

THIS FORM MUST BE COMPLETED BY AN APPLICABLE LICENSED CONTRACTOR (mechanical, plumbing, electrical).
ALL ITEMS MUST BE EVALUATED AND MARKED OR THE FORM CANNOT BE ACCEPTED.

PROPERTY ADDRESS 703 Northwestern

FURNACE: Circle One: Electric Gas

Make: <u>Amana</u>	Model: <u>GHE120DM4</u>				
Serial Number: <u>BL82250623</u>	Approximate Age: <u>42 yrs old</u>				
Btu's: <u>120,000</u>	Filter Size: <u>N/A not available</u>				
Venting (circle one): Direct	Power Natural Draft				
Chimney (circle one): Lined	Unlined Type B-Vent				
	Pass	Fail		Pass	Fail
Carbon Monoxide Test	X		Combustion Air		X
Fuel/Venting System	X		Gas Shut Off Valve		X
Gas Valve	X		Electric Shut Off		X
Heat Exchanger	X		Condensate Drain Line		X
Burners			Drip Leg on Gas Line		X
Burner/Fan Safety Devices	X		PPM Reading		X
Proper Breaker or Fuse (Electric)	X		Protection for NM Cable (Electric)		X
FURNACE (circle one):	SAFE			UNSAFE	

WATER HEATER/BOILER: Circle One: Electric Gas

Make:	Model:				
Serial Number:	Approximate Age:				
Venting (circle one): Direct	Power Natural Draft				
Chimney (circle one): Lined	Unlined Type B-Vent				
	Pass	Fail		Pass	Fail
Positive Drafting			Isolation Water Valve		
Fuel/Venting System			Gas Shut Off Valve		
T and P Relief Valve & Discharge			Drip Leg on Gas Line		
Burner Cover			Combustion Air		
Electric Shut Off (Boiler Only)			Low Water Cut Off (Boiler Only)		
Proper Breaker or Fuse (Electric)			Electrical Connections (Electric)		
Protection for NM Cable (Electric)			Other:		
Water Heater (circle one):	SAFE			UNSAFE	
Boiler (circle one):	SAFE			UNSAFE	

I hereby certify that the above information is true and correct.

Date of Service 1-31-24

Technician Signature J. Reck

Company Name

Redmond HVAC

(please print)

Phone Number 5156205891

Inspection Division/515 Clark Ave, Ames, IA 50010/515-239-5153

Email to: inspections@cityofames.org

Revised 5/15/19