
Disclosure incompleteness, measured in litres
(a) What each disclosure actually pins down
mean U_j = 0.906 — the interval is 91% as wide as its own midpoint
CtrlS
Sify
Amazon (AWS)
Bharti Airtel (Nxtra)
ST Telemedia GDC
Microsoft
Adani (AdaniConneX)
Google
NTT DATA
U_j = 0.572
4.24–7.64
U_j = 0.572
4.24–7.64
U_j = 0.620
4.31–8.18
U_j = 0.729
3.81–8.19
U_j = 0.729
3.81–8.19
U_j = 1.109
2.39–8.33
U_j = 1.273
2.27–10.22
U_j = 1.273
2.27–10.22
U_j = 1.273
2.27–10.22
three operators share one interval: nothing they publish constrains the identity at all
0
2
4
6
8
10
12
feasible WUE_{source} (L / kWh)
(b) Which missing field costs the most
WUE-site with stated boundary + denominator
not required
35.5%
Heat-rejection architecture, per facility (A1–A6)
not required
33.7%
PUE, India portfolio or per facility
not required
17.0%
Renewable share of electricity supply
12.6%
Facility location / climate zone
1.3%
86.2% of the achievable reduction sits in fields BRSR does not require
not required by BRSR
required by BRSR (location: count only)
0
10
20
30
40
mean reduction in source-water uncertainty (% of achievable)