

Parameter setting:

P48=0 disable DHW tank temperature sensor (default)

L12=1 disable high temperature sterilization (default)

P164 is used to control cascade. Please refer to Chapter 2.7.7 for specific setting methods.

Refer to Section 2.5.5.7 for wiring.

Refer to Chapter 1.3.5.1 to set slave unit.

| No. | Name | No. | Name |
|-----------------|-----------------------------------|------------------|--|
| 1 | Air Vent Valve (Built-in) | P_a | Built-in Water Pump (Built-in) |
| 2 | Water Flow Switch (Built-in) | P_b | Heating/Cooling Water Pump (Field Supply) |
| 3 | Safety Valves (Built-in) | P_c ¹ | Auxiliary Water Pump (Field Supply) |
| 4 | Expansion Tank (Built-in) | EH2 | Electric Heater (Field Supply) |
| 5 | Ball Valves (Field Supply) | SV2 | 3-Way Valve (Field Supply) |
| 6 | Filter (Field Supply) | T15 | Water Outlet Temp. Sensor (Built-in) |
| 7 | Non-Return Valves (Field Supply) | T8 | Water Inlet Temp. Sensor (Built-in) |
| 8 | Bypass Valves (Field Supply) | T10 ² | Buffer Tank Temp. Sensor (Built-in) |
| 9 | Buffer Tank (Field Supply) | T9 | Total Water Outlet Temp. Sensor (Built-in) |
| 10 | Underfloor Heating (Field Supply) | | |
| 11 | Fan Coil (Field Supply) | | |
| 12 ³ | Heat Pump Cascade | | |

1. If the unit is too far away from the buffer tank or the domestic water tank coil is too long, it is necessary to increase the installation of this pump to auxiliary circulation.

2. This sensor needs to be enabled when opening the dual-temperature zone control.

NOTE: The installation diagram is for reference only and installation is subject to actual conditions.

2.7 Unit Operation

This section only introduces the setting parameters and operation introduction of common modes and some parts, for more parameters, please refer to section 4.3.

2.7.1 Running Mode

It mainly introduces the operation mode and setting parameters of several operation modes of the unit.

2.7.1.1 Silent Mode

When running this mode, the unit will reduce the compressor frequency and fan frequency to make the unit less noisy. The maximum compressor frequency and fan frequency will be limited to P88 and P89.

| Parameter | Default Value/Range/Unit | Description |
|--|--------------------------|---|
| P88 | 50 (20-70) /Hz | Max. compressor operating frequency |
| P89 | 40 (20-60) /Hz | Max. fan operating frequency (RPM=Hz*15) |
| NOTE: Lower frequency leads to lower unit capacity Example: Turn on the silent mode, the maximum operating frequency of the compressor will be limited to 50Hz, and the maximum operating frequency of the fan will be limited to 40Hz. | | |

2.7.1.2 Powerful Mode

To run this mode, the unit will operate by increasing the compressor ramp-up speed and maximum operating frequency, which is then controlled by P179 and P180.

| Parameter | Default Value/Range/Unit | Description |
|--|--------------------------|-------------------------------------|
| P179 | 15 (0-40) /Hz | Power mode frequency increase |
| P180 | 5 (0-40) /Hz | Power mode frequency limit increase |
| Example: Turning on the Power Mode increases the compressor frequency by 15 Hz each time, and the maximum frequency will be increased by 5 Hz from the original maximum compressor operating frequency. | | |

2.7.1.3 Sterilization Mode

When the unit is enabled for hot water mode, you can choose to enable the sterilization mode, and the sterilization mode parameters are set according to the following parameters.

| Parameter | | Default Value/Range/Unit | Description | Note |
|-----------|-----|--------------------------|-----------------------------------|---|
| L12=2 | / | / | Manually enter sterilization mode | Refer to sections 3.1.3.1 and 3.2.3.1 for entry method. |
| L12=1 | / | / | Disable sterilization mode | |
| L12=0 | L13 | 7 (5-30) /Day | Days between sterilizations | Sterilization cycle |
| | L14 | 23:00 (0-24) | Sterilization start-up time | Sterilization mode start time point |
| | L15 | 10 (0-50) /Min | Sterilization running time | Sterilization mode continuous running time |

| Parameter | | Default Value/Range/Unit | Description | Note |
|--|-----|--------------------------|----------------------------|--------------------------------------|
| | L16 | 70 (50-80) /°C | Sterilization temp setting | Sterilization mode water temperature |
| NOTE: When the unit is enabled for electric heater, the sterilizing mode will be turned on demand. Example: When the sterilization mode is enabled, the unit will run sterilization once at 23:00 and 7 days interval, the sterilization will continue to run at 70 °C water temperature for 10Min and then exit; the next time it will be turned on will be at 23:00 after 7 days. | | | | |

2.7.1.4 Quick Heating Mode

The unit will turn on the electric heater and auxiliary heat source to achieve rapid heating, please refer to 2.7.2 for specific operation.

2.7.2 Electric Heater/AHS

Explanation of the operation and parameters of electric heaters for different locations.

The following parameters and conditions control the switching on and off electric heater:

| Electric Heater Type | Turn On | Turn Off |
|---|---|--|
| EH2 | Ambient Temperature ≤ P22 And Water Inlet Temperature < Setting Temperature - P26 | Ambient Temperature ≥ P22+3 Or Reach Setting Temperature |
| EH1 | Ambient Temperature ≤ P22 And DHW Tank Temperature < Setting Temperature - P96 | DHW Tank Temperature ≥ Setting Temperature |
| NOTE: P22=-7 °C(Default); P26=5 °C(Default); P96=5 °C(Default) | | |

2.7.2.1 Electric Heater of Buffer Tank (EH2) / Electric Heater of DHW Tank (EH1) /AHS

If the tank is installed with electric heater and parameters P139/P140 are used for electric heater or auxiliary heat source turn on, then the parameters need to be configured as follows, for wiring please refer to section 2.5.1.

| Parameter | Setting Value | Description |
|-----------|----------------|--|
| P139 | 0 (Default) | Enable buffer tank electric heater |
| | 1 | Disable buffer tank electric heater |
| | 2 | Enable auxiliary heat source for heating |
| P140 | 0 (Default) | Enable DHW tank electric heater |
| | 1 | Disable DHW tank electric heater |
| | 2 | Enable auxiliary heat source for DHW |

2.7.2.2 Electric Heater of Water Pipes

If electrical pipe heater is added to the installation, then the P182 parameter needs to be set as shown in the table.

| Parameter | Setting Value | Description |
|-----------|---------------|--------------------------------------|
| P182 | 0 | Enable pipe electric heater(3kW+6kW) |
| | 1 | Disable pipe electric heater(3kW) |
| | 2 | Disable pipe electric heater(6kW) |
| | 3 | Disable pipe electric heater |
| | 4 | Forced enable pipe electric heater |

2.7.3 Water Pump

This section explains how each water pump in the system operates.

2.7.3.1 Built-in Water Pump (P_a)

The operation of the unit's built-in circulating water pump is controlled by parameter P28, the settings of which are shown in the table below:

| Parameter | Setting Value | Description | Note |
|-----------|----------------|--|---|
| P28 | 0 | Water pump run continuously after the unit reaches the target temperature | |
| | 1 (Default) | After the unit reaches the target temperature, water pump runs at a cycle of 2Min every 10Min. | |
| | 2 | In cooling mode, the water pump runs continuously after the unit reaches the target temperature. | For cooling mode only, other modes operate as P28=1. |
| | 3 | In cooling and heating mode, the water pump runs continuously after the unit reaches the target temperature. | For cooling/heating mode only, other modes are operated according to P28=1. |
| | 4 | In heating mode, the pump runs continuously after the floor heating reaches the target water temperature | For underfloor heating water temperature only, other modes operate as P28=1 |

In addition, P_a water pumps use different brands and models of water pumps, the corresponding P146 parameters are not the same, if the maintenance of the replacement of different brands of water pumps, you need to follow the table corresponding to the model and parameter settings.

| Water Pump | | Unit | P146 |
|------------|--------------------|---|------|
| Brand | Model | | |
| SHIMGE | APM25-9-130 | HH-C1-6 HH-C1-8 HH-C3-8 HH-C1-12 HH-C3-12 | 66 |
| | APF25-12-130EFPWM1 | HH-C1-18 HH-C3-18 | 62 |
| GRUNDFOS | UPM3K/25-75/130 | HH-C1-6 | 66 |
| | UPML/25-105/130 | HH-C1-8 HH-C3-8 HH-C1-12 HH-C3-12 | 66 |
| | UPMXL/25-125/130 | HH-C1-18 HH-C3-18 | 62 |

NOTE: P146 is set correctly for correct flow feedback from water pumps.

2.7.3.2 Heating/Cooling Water Pump (P_b)

The water pump is used as a circulating water pump in the heating circuit and the mode of operation is controlled by parameter P150, the settings of which are shown in the table below:

| Parameter | Setting Value | Description | Note |
|-----------|-----------------------|--|--|
| P150 | 1 | The water pump starts when the unit is turned on or when it reaches temperature and stops. | |
| | 2 (Default) | The water pump is controlled via room thermostat | <p>When P150=2, it is necessary to connect the room thermostat</p> |
| | 3 | The water pump is controlled via the wired controller | Wired controller with built-in temperature sensor for use as a room thermostat |

2.7.3.3 Auxiliary Water Pump (P_c)

Since the head of the built-in circulating water pump is fixed, if you need to add additional pumps to meet the system demand in the actual installation, you can set different parameters for the installation position of the auxiliary pump, please refer to section 2.5.1 for the wiring.

| Parameter | Setting Value | Description | Diagram |
|--|----------------|---|---|
| P161 | 0 (Default) | Auxiliary pumps for DHW | |
| | 1 | Auxiliary pumps for cooling/heating circuits | <p>For Single Circulation System</p> |
| | | | |
| | 2 | Auxiliary pumps for underfloor heating | <p>For Single Circulation System</p> |
| | | | |
| | 3 | Auxiliary pumps for cooling/heating and underfloor heating circuits | |
| | 4 | Auxiliary pumps for unit circulation | |
| NOTE: When running the corresponding mode, when the main unit circulation pump starts, the unit auxiliary pump starts at the same time. | | | |

2.7.3.4 DHW Return Water Pump (P_d)


The water pump is used for domestic water tank and user use side, can make the domestic hot water temperature in the house to maintain the temperature of the temperature, the control parameters are controlled by L22, the parameters of the temperature of the circulating return water are controlled by L23 and L24, and the cycle and time of the return water are controlled by L25 and L26, the specific setup and mode of operation are shown in the following table:

| Parameter | Setting Value | Description | Note |
|-----------|----------------|---|---|
| L22 | 0 (Default) | Disable DHW return water function | |
| | 1 | Enable the water return function and keep the water pump on | |
| | 2 | Enable the water return function and control the water return function according to the cycle. Currently, the water pump runs L26 after every L25 | L25: Default 30Min(3-90Min) L26: Default 5Min(1-30Min) |
| | 3 | Enable the water return function and control the water return function according to the temperature difference. At this time, if the return water temperature $L23 \leq L23-L24$, then enable the water return function, and stop after reaching the temperature | L23: Default 40°C(20-65°C) L24: Default 5°C(1-15°C) |

Example:

When L22=2, the pump will run for 5 Min every 30 Min to maintain the water temperature in the water pipes in the house.

When L22=3 and the set return temperature is 40 °C, the return function will be enabled when the temperature in the water pipe is lower than $40-5=35$ °C, and will be turned off when the water temperature reaches 40 °C.



2.7.3.5 AHS Water Pump (P_e)

When the system is connected to solar water heater, the unit starts the solar water heater by controlling this water pump. The water pump is controlled by parameters P151 and P152, which are set in the following table:

| Parameter | Default Value/Range/Unit | Description | Note |
|--|--------------------------|--|--|
| P151 | 10 (0-40) /℃ | DHW tank heat source return temperature | When the solar water heater water pump is used in the hot water tank |
| P152 | 10 (0-40) /℃ | Buffer tank heat source return temperature | When the solar water heater water pump is used in the buffer tank |
| NOTE: Turn on: Hot water/buffer side heat source temperature > hot water/buffer tank temperature + P151/P152 Turn off: Hot water/buffer side tank temperature < hot water set temperature | | | |

2.7.4 Three-Way Valve

This section explains how the three-way valve operates in the system.

2.7.4.1 SV1#Three-Way Valve

This three-way valve is used to switch between DHW-buffer tank. When switching heating/hot water modes, use the three-way valve to switch the water line, see the following table for specific operation:

| Running Mode | Terminal Block No. | Status | Control Type |
|---|--------------------|--------|--------------|
| Hot Water | 7# | 230V | Type 1 |
| | 8# | 0V | |
| Heating/Cooling (Buffer Tank) | 7# | 0V | |
| | 8# | 230V | |
| NOTE: When repairing, you can use a multimeter to detect whether the heat pump has normal voltage output to the three-way valve | | | |

2.7.4.2 SV2#Three-Way Valve

This three-way valve is used to switch fan coil- underfloor heating, when switching working mode, the three-way valve is used to switch the water circuit, the specific operation is shown in the following table:

| Running Mode | Terminal Block No. | Status | Control Type |
|---|--------------------|--------|--------------|
| Underfloor Heating | 9# | 230V | Type 1 |
| | 10# | 0V | |
| Fan Coil (Heating/Cooling) | 9# | 0V | |
| | 10# | 230V | |
| NOTE: When repairing, you can use a multimeter to detect whether the heat pump has normal voltage output to the three-way valve | | | |

2.7.4.3 SV3#Three-Way Valve (Mixing Valve)

When the dual zone temperature control is enabled for underfloor heating mixing, see the table below for specific operation:

| Three-Way Valve Status | Terminal Block No. | Status | Control Type |
|------------------------|--------------------|--------|--------------|
| Close | A3# | 230V | Type 1 |
| | A4# | 0V | |
| Open | A3# | 0V | |
| | A4# | 230V | |

NOTE: When repairing, you can use a multimeter to detect whether the heat pump has normal voltage output to the three-way valve

2.7.5 Linkage Switch

The linkage switch is a dry contact signal, indicating both open and closed states.



| Terminal Block No. | Description | Operating Principle | Note |
|--------------------|--------------------------------------|---|--|
| 15-20 | Forced Cooling Switch | When closed, the unit running cooling mode, typically used to connect thermostats that can switch between operating modes | Open by default, no parameter setting required |
| 16-20 | Linkage Switch (External Water Pump) | Used to connect room thermostat to control the P_b Water Pump turn ON/OFF | |
| 17-20 | Forced Heating Switch | When closed, the unit running heating mode, typically used to connect thermostats that can switch between operating modes | |
| 18-20 | Linkage Switch (Heat Source of DHW) | Usually used to connect solar water heater | |
| 19-20 | Linkage Switch | Used to connect room thermostat, to control the unit, setup parameters refer to section 2.7.5.1 | Controlled by parameter P05 |

NOTE: There is no voltage output from the linkage switch, it is just a passive signal.

2.7.5.1 Room Thermostat

Connect the room thermostat and use the room temperature to control the unit on and off.

| Parameter | Setting Value | Description | Example |
|-----------|----------------|--|--|
| P05 | 0 (Default) | Enable the linkage switch Closed: Turn on Opened: Turn off (DHW included) | When the linkage switch is closed, the heat pump will turn on when there is a demand to turn on the heat pump. When the linkage switch is opened, the heat pump will not turn on, and will not turn on when there is a demand for DHW |
| | 1 | Disable the linkage switch | Disable the linkage switch |

| | | | |
|--|---|--|---|
| | 2 | Enable the linkage switch Closed: Turn on Opened: Unit enter the standby mode | When the linkage switch is closed, the heat pump will turn on when there is a demand to turn on the heat pump. When the linkage switch is opened, the heat pump enters standby mode, but the water pump operates in the mode that has been set. |
| | 3 | Enable the linkage switch Closed: Turn on Opened: Turn off (DHW not included) | When the linkage switch is closed, the heat pump will turn on when there is a demand to turn on the heat pump. When the linkage switch is opened, the heat pump will not turn on, but when there is a demand for DHW, it will switch to DHW mode operation |
| Opened  | | Closed  | |

2.7.6 Dual Temperature Zone

When the house at the same time using the radiator and floor heating, need to set different water temperature, this time you need to turn on the unit's dual-temperature zone function, the unit through the control of the mixing valve and mixing pump to achieve the floor heating temperature regulation. Currently, the parameter settings refer to the following table:

| Parameter | Setting Value | Description | Note |
|-----------|----------------|--|--|
| P257 | 0 | Enable dual temperature zones when the unit is turned on | Corresponds to the temperature sensor: T11: Enable temperature zone 2 temperature. T10: Enable buffer tank temperature |
| | 1 | Enable dual temperature zones on demand | |
| | 2 (Default) | Disable dual temperature zones | |
| P258 | / | Mixing valve adjustment cycle | Factory parameter adjustment is recommended to consult the manufacturer |
| P259 | / | Mixing valve closure duration | |
| P265 | / | Mixing valve single adjustment percentage | |

2.7.7 Cascade

If more than one unit needs to be installed at the same time, it is necessary to turn on the cascade function for unit control, refer to section 1.3.5.1 for the dialing method, and refer to section 2.6.4 for wiring and installation. For specific parameter settings, please refer to the following table:

| Parameter | Setting Value | Description | Note |
|-----------|----------------|--|---|
| P164 | 0 | Enable cascade intelligent control mode | Parameters P165-P170 take effect when enabled |
| | 3 (Default) | Disable cascade intelligent control mode | |
| P165 | 3°C | Loaded unit return temperature | Controls whether to turn on the next unit |
| P166 | 2°C | Derating unit return temperature | Controls whether to turn off the next unit |

| | | | |
|--|------|--|--|
| P167 | 3°C | Emergency stops return temperature | Controls whether to turn off the unit |
| P168 | 50% | Hot water mode unit activation ratio | Limit the total number of starting units |
| P169 | 100% | Heating/Cooling mode unit activation ratio | Limit the total number of starting units |
| P170 | 7Min | Load unit cycle | Time to activate the next unit |
| NOTE: Factory parameter adjustment is recommended to consult the manufacturer | | | |

2.7.8 SG Ready

If the unit is connected to the smart grid, this function can be enabled via parameter P255, refer to section 2.5.4 for wiring, and the unit will run in different modes according to the signals received:

| Parameter | Status (0:Open 1:Close) | | Running Mode | Description |
|---------------------|----------------------------|----|--|---|
| | EVU | SG | | |
| P255=0 | 1 | 1 | Running DHW Mode | 1. Set the hot water temperature to the sterilization temperature. 2. Turn on electric heater |
| | 1 | 0 | Running DHW Mode | 1. Set the hot water temperature to the sterilization temperature. 2. Turn on electric heater |
| | 0 | 1 | Running current mode | |
| | 0 | 0 | Turn off hot water mode and enter ECO mode | 1. Turn off the hot water mode, turn off the electric heater 2. Turn off after running P256 Min (default 3Min) |
| P255=1 (Default) | Disable | | | |

2.7.9 Anti-Freeze Protection

In cold weather in winter, to protect the unit and water pipes, the unit will automatically enter the anti-freeze protection mode according to the ambient temperature and the water outlet temperature. The parameter of the unit is as follows:

| Parameter | Setting Value | Description |
|-----------|------------------|---|
| P117 | 5°C(0°C-10°C) | Ambient temperature for antifreeze protection |
| P118 | 3°C(0°C-20°C) | Water outlet temperature for anti-freeze protection |
| P29 | 2min(0min-20min) | Water pump runtime with freeze protection |

The heat pump will judge whether to enter the anti-freeze protection according to the ambient temperature and water temperature under standby condition, and the unit has two levels of anti-freeze protection, which correspond to different operation modes. When the hot water function is turned on, it will increase the domestic hot water tank temperature determination. Please refer to the following table for detail:

| Anti-Freeze Level | Type | Entry Condition | Exit Condition | Unit Operate in Anti-Freeze Protection |
|-------------------|---------------|---|---|--|
| I | Heating | Ambient Temp. $\leq P117$ | Ambient Temp. $\geq P117+3^{\circ}\text{C}$ | P_a pumps every 10 minutes then run P29 minutes |
| II | Heating | Ambient Temp. $\leq P117$ and Water Outlet Temp. $\leq P118$ | Ambient Temp. $\geq P117+3^{\circ}\text{C}$ or Water Outlet Temp. $\geq 15^{\circ}\text{C}$ | Running heating mode and turn on electric heater |
| | Heating + DHW | Ambient Temp. $\leq P117$ and DHW Water Tank Temp. $\leq P118$ | Ambient Temp. $\geq P117+3^{\circ}\text{C}$ or Water Outlet Temp. $\geq P118+12^{\circ}\text{C}$ | Running heating mode and turn on electric heater |

** Please note that if the unit is running in standby mode, it is possible that it has entered the freeze protection mode.*

2.8 Basic Running Logic & Setting

This chapter mainly explains the basic operation logic of the unit, including the heating mode of the unit, the startup and shutdown conditions of the cooling mode and hot water mode, the operation mode of the unit after it reaches the set temperature, and the water temperature control mode of the unit, etc. The following will be an explanation of some of the terms and parameters used, so that the corresponding parameters can be better understood and set.

| Parameter | Description | Explanation |
|---|---|---|
| P26 | *Temperature difference of heating and cooling(ΔT_{P26}) | It is used to control the on/off parameter in heating mode or cooling mode, when the current water temperature of the unit is greater than the sum of the set water temperature and the parameter or less than the difference between the set water temperature and the parameter, the unit will be on/off. |
| P27 | *Temperature difference of underfloor heating(ΔT_{P27}) | It is used to control the on/off parameter in floor heating mode, when the current water temperature of the unit is greater than the sum of the set water temperature and this parameter or less than the difference between the set water temperature and this parameter, it will enter on/off. |
| P37 | When the unit reaches the set temperature, choose to control the operation mode of the compressor | 0: The unit will not shut down immediately after reaching the set temperature, and it needs to be determined whether to shut down or not according to the running frequency and length of the compressor. |
| | | 1: Shutdown after reaching the target water temperature, the unit will shut down immediately after reaching the set temperature. |
| | | 2: The unit will enter the intelligent shutdown mode when running the cooling mode and will enter the temperature shutdown when running the heating mode. |
| P96 | *Temperature difference of DHW(ΔT_{P96}) | It is used to control the on/off parameter in DHW mode |
| P116 | Unit temperature control mode | 1: The unit is controlled by the water OUTLET temperature, at this time the real-time temperature displayed on the wired controller is the water temperature at the water outlet of the unit. |
| | | 0: The unit is controlled by the INLET water temperature, at this time the real-time temperature displayed on the wired controller is the water temperature at the inlet of the unit. |
| <i>* Temperature Difference: To prevent the unit from frequent off and on, this parameter is set to regulate the unit off and on.</i> | | |
| <i>Note:</i> | | |
| P26=0 ℃ (Default) ;P27=0 ℃ (Default) ;P96=5 ℃ (Default) ;P116=1 (Default) | | |

2.8.1 Temperature Difference Setting (ΔT)

In general, this parameter is not recommended to be changed, and this section describes the basic settings of the temperature difference. The following is expressed using ΔT .

When running hot water mode, the temperature differential setting is parameter P96.

When running the heating mode, the temperature differential setting is parameter P26. At this time, when $P26 \neq 0$, the unit's temperature differential is set according to P26; when $P26 = 0$, the unit's temperature differential value is calculated by the following formula:

$$\Delta T_{P26} = \frac{\text{Water Inlet Temperature}}{10}$$

ΔT_{P26} calculated then take 2°C-5°C

For example, if current water inlet temperature is 46°C, then $\Delta T_{P26}=4.6^{\circ}\text{C}=4^{\circ}\text{C}$

When running the cooling mode, the temperature difference is set with parameter P26, at this time, when P26 $\neq 0$, the temperature difference of the unit is set according to P26; when P26 = 0, the value of the temperature difference of the unit is calculated by the following equation:

$$\Delta T_{P26} = 5 - \frac{\text{Water Inlet Temperature}}{10}$$

ΔT_{P26} calculated then take 2°C-5°C

For example, if current water inlet temperature is 15°C, then $\Delta T_{P26}=1.5^{\circ}\text{C}=1^{\circ}\text{C}$

When running the underfloor heating mode, the temperature difference is set with parameter P27, at this time, when P27 $\neq 0$, the temperature difference of the unit is set according to P27; when P27 = 0, the value of the temperature difference of the unit is calculated by the following equation:

$$\Delta T_{P27} = \frac{\text{Water Inlet Temperature}}{10}$$

ΔT_{P27} calculated then take 2°C-5°C

For example, if current water inlet temperature is 36°C, then $\Delta T_{P27}=3.6^{\circ}\text{C}=3^{\circ}\text{C}$

Parameter P26/P27 is factory set to 0°C, so the temperature difference of the unit is calculated according to the inlet water temperature.

2.8.2 Heating Mode

When the unit is running the heating mode, please refer to the following table for the unit's on and off conditions:

| P116 | P37 | Turn On Condition | Turn Off Condition |
|----------------|----------------|---|--|
| 1 (Default) | 0 (Default) | Water Outlet Temperature < Setting Temperature - ΔT_{P26} * ΔT | Water outlet temperature \geq setting temperature and compressor at the lowest frequency (Fmin) continuous operation $\geq 5\text{min}$ Or Water outlet temperature \geq Setting temperature +3°C |
| | 1/2 | * $\Delta T = \text{Water Outlet Temperature} - \text{Water Inlet Temperature}$ (Temperature difference at heat pump shutdown) | Water outlet temperature \geq Setting temperature |
| 0 | 0 | Water Inlet Temperature < Setting Temperature - ΔT_{P26} | Water inlet temperature \geq setting temperature and compressor at the lowest frequency (Fmin) continuous operation $\geq 5\text{min}$ Or |

| | | | |
|--|-----|--|---|
| | | | Water inlet temperature \geq Setting temperature $+3^{\circ}\text{C}$ |
| | 1/2 | | Water inlet temperature \geq Setting temperature |

2.8.3 Underfloor Heating Mode

When the unit is running the underfloor heating mode, please refer to the following table for the unit's on and off conditions:

| P116 | P37 | Turn On Condition | Turn Off Condition |
|----------------|----------------|--|--|
| 1 (Default) | 0 (Default) | Water Outlet Temperature $<$ Setting Temperature $- \Delta T_{P27} - * \Delta T$ * ΔT = Water Outlet Temperature – Water Inlet Temperature (Temperature difference at heat pump shutdown) | Water outlet temperature \geq setting temperature and compressor at the lowest frequency (Fmin) continuous operation $\geq 5\text{min}$ Or Water outlet temperature \geq Setting temperature $+3^{\circ}\text{C}$ |
| | 1/2 | | Water outlet temperature \geq Setting temperature |
| 0 | 0 | Water Inlet Temperature $<$ Setting Temperature $- \Delta T_{P27}$ | Water inlet temperature \geq Setting temperature and compressor at the lowest frequency (Fmin) continuous operation $\geq 5\text{min}$ Or Water inlet temperature \geq Setting temperature $+3^{\circ}\text{C}$ |
| | 1/2 | | Water inlet temperature \geq Setting temperature |

2.8.4 Cooling Mode

When the unit is running cooling mode, please refer to the following table for the unit's on and off conditions:

| P116 | P37 | Turn On Condition | Turn Off Condition |
|----------------|-----|--|--|
| 1 (Default) | 0/2 | Water Outlet Temperature $>$ Setting Temperature $+ \Delta T_{P26} + * \Delta T$ * ΔT = Water Outlet Temperature – Water Inlet Temperature (Temperature difference at heat pump shutdown) | Water Outlet Temperature \leq Setting temperature and compressor at the lowest frequency (Fmin) continuous operation $\geq 5\text{min}$ Or Water Outlet Temperature \leq Setting temperature -3°C |
| | 1 | | Water Outlet Temperature \leq Setting temperature |
| 0 | 0/2 | Water Inlet Temperature $>$ Setting Temperature $+ \Delta T_{P26}$ | Water inlet temperature \leq Setting temperature and compressor at the lowest frequency (Fmin) continuous operation $\geq 5\text{min}$ Or Water inlet Temperature \leq Setting temperature -3°C |

| | | | |
|--|---|--|---|
| | 1 | | Water Outlet Temperature \leq Setting temperature |
|--|---|--|---|

2.8.5 DHW Mode

When the unit is running DHW mode, please refer to the following table for the unit's on and off conditions:

| Turn On Condition | Turn Off Condition |
|--|---|
| DHW Tank Temperature $<$ Setting Temperature - ΔT_{P96} | DHW Tank Temperature \geq Setting Temperature |
| *When the unit is running hot water mode together with other modes, hot water mode is given priority whenever hot water is demanded. | |

4.2 Error Code

4.2.1 Motherboard

| Error Code | Error Description | Troubleshooting |
|------------|---|--|
| E01 | Wrong Phase | Power Supply Connect Wrong Phase |
| E02 | Missing Phase | Power Supply Missing Phase |
| E03 | Water Flow Failure | 1.Check whether the circulating water pump is normal and whether the water system is blocked. |
| | | 2.Check whether the water flow switch is normal and whether the installation direction is correct. |
| | | 3.Check whether the wiring of the water flow switch is correct or not. |
| | | 4.Check whether the water pump head meets the actual requirements |
| | | 5.Check whether the water pump is reversed and installed in the wrong direction. |
| E04 | Abnormal Communication between Motherboard and Remote Module (Reserved) | Check the communication connection between the motherboard and the remote module |
| E05 | High Pressure Switch Failure | 1.Check pressure switch for damage, wiring error |
| | | 2.Check if there is too much refrigerant in the system. |
| | | 3.Check whether the fan is working properly and whether the water flow of the unit is normal. |
| | | 4.Check whether there is air or blockage in the fluorine system. |
| | | 5.Check whether the water-side heat exchanger is seriously caked with whitewash. |
| E06 | Low Pressure Switch Failure | 1.Check pressure switch for damage, wiring error |
| | | 2.Check if there is not enough refrigerant in the system. |
| | | 3.Check whether the fan is working properly |
| | | 4.Check whether there is air or blockage in the fluorine system. |
| E09 | Wire Controller Communication Failure | Check the communication connection between the wire controller and the main board |
| E10 | Reserve | Reserve |
| E11 | Out of Use Time | The free trial period has expired, enter the boot password |

| Error Code | Error Description | Troubleshooting |
|------------|--|---|
| E12 | Exhaust Temp. Too High | 1. Fluorine system clogging |
| | | 2. Lack of refrigerant in the fluorine system or bad sensor |
| E14 | DHW Tank Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E15 | Water Inlet Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E16 | Outer Coil Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E18 | Exhaust Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E20 | Indoor Ambient Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E21 | Outdoor Ambient Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E22 | DHW Return Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E23 | Water Outlet Temp. Too Low in Cooling Mode | 1. Check whether the water flow is too low or no water flow |
| | | 2. Check if the water outlet sensor is damaged |
| | | 3. Fluorine system clogging |
| E24 | Antifreeze Temp. Sensor Failure (Fluorine Circuit) | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E25 | Reserve | Reserve |
| E26 | Antifreeze Temp. Sensor Failure (Water Circuit) | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |

| Error Code | Error Description | Troubleshooting |
|------------|---|---|
| | | 3. The motherboard port is damaged |
| E27 | Water Outlet Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E29 | Suction Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E30 | Suction Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E31 | Water Pressure Failure | 1. Water pressure switch wiring error |
| | | 2. Water pressure switch failure |
| E32 | Water Outlet Temp. Sensor T15 Failure | 1. Water flow is not enough |
| | | 2. Sensor failure |
| E33 | High Pressure Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E34 | Low Pressure Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E37 | Large Temp. Difference between Water Inlet and Outlet | 1. The water inlet or outlet sensor is damaged |
| | | 2. Water inlet or outlet sensor not placed or in the wrong position |
| | | 3. Water flow is not enough |
| E38 | Fan Failure | Fan driver board or motor failure |
| E42 | Cooling Coil Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E44 | Ambient Temp. Too Low | Normal protection |
| E47 | Economizer Inlet Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E48 | Economizer Inlet Temp. Sensor | 1. The sensor wire is loose or damaged |

| Error Code | Error Description | Troubleshooting |
|------------|--|--|
| | Failure | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| E49 | Economizer Outlet Temp. Sensor Failure | Same as E47 |
| E51 | High Pressure Too High | Same as E05 |
| E52 | Low Pressure Too Low | Same as E06 |
| E55 | Expansion Board Communication Failure | 1. Poor contact or broken signal wire |
| | | 2. Expansion board damage |
| | | 3. Motherboard damage |
| E80 | Power Supply Error | Single-phase power supply unit detects a three-phase electrical signal |
| E88 | Inverter Drive Module Protection | Compressor or compressor driver board is damaged, specific faults see 4.2.2 |
| E94 | Built-in pump over/under voltage | 1. Input power supply voltage < 165V |
| | | 2. Input power supply voltage > 265V |
| | | 3. Electronic components on the pump drive board are damaged or damp |
| | | 4. Water pump failure |
| E96 | Compressor Drive Board Communication Failure | 1. Poor contact or broken signal wire |
| | | 2. Electronic components on the motherboard are damaged or damp. |
| | | 3. Compressor drive board on the electronic components are damaged or moisture |
| | | 4. Compressor drive board power supply is not powered on |
| E98 | Fan Board Communication Failure | 1. Poor contact or broken signal wire |
| | | 2. Electronic components on the motherboard are damaged or damp. |
| | | 3. Fan drive board on the electronic components are damaged or moisture |
| | | 4. Fan drive board power supply is not powered on |
| EA1 | Cascade Model Mismatch | Different series of units are not allowed to be cascaded |
| EA2 | Solar Water Heater Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| EA3 | Zone 2 Temp. Sensor Failure | 1. The sensor wire is loose or damaged |

| Error Code | Error Description | Troubleshooting |
|------------|---|--|
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| | | |
| EA4 | Buffer Tank Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |
| EA5 | Total Water Outlet Temp. Sensor Failure | 1. The sensor wire is loose or damaged |
| | | 2. Sensor is damaged |
| | | 3. The motherboard port is damaged |

4.2.2 Driver Board (Compressor)

| Compressor Drive Error Description Table | | |
|--|-----|---|
| E88 | P1 | IPM Module Overheat and Shutdown |
| | P2 | Compressor Driver Failure |
| | P3 | Compressor Overcurrent |
| | P4 | Input Voltage Missing Phase |
| | P5 | IPM Supply Voltage Failure |
| | P6 | Power Component Overheating and Shutdown |
| | P7 | Pre-charge Circuit Voltage Failure |
| | P8 | DC Bus Overvoltage |
| | P9 | DC Bus Undervoltage |
| | P10 | AC Input Undervoltage |
| | P11 | AC Input Overvoltage |
| | P12 | Input Voltage Sampling Failure |
| | P13 | DSP and PFC Communication Failure |
| | P14 | Board Radiator Temp. Sensor Failure |
| | P15 | DSP and Communicate Board Communication Failure |
| | P16 | Communication Failure with Motherboard |
| | P17 | Compressor Overcurrent Alarm |
| | P18 | Compressor Weak Magnetic Protection Alarm |
| | P19 | IPM Overheat Alarm |
| | P20 | PFC Overheat Alarm |
| | P21 | AC Input Overcurrent Alarm |
| | P22 | EEPROM Error Alarm |
| | P23 | N/A |

| Compressor Drive Error Description Table | | |
|---|-----|---|
| | P24 | EEPROM Refresh Complete |
| | P25 | Temperature Sensing Failure Limit |
| | P26 | AC Undervoltage Frequency Limit Protection Alarm; |
| | P27 | N/A |
| | P28 | N/A |
| | P29 | N/A |
| | P30 | N/A |
| | P31 | N/A |
| | P32 | N/A |
| | P33 | IPM Module Overheat and Shutdown |
| | P34 | Compressor Missing Phase |
| | P35 | Compressor Overload |
| | P36 | Input Current Sampling Failure |
| | P37 | IPM Supply Voltage Failure |
| | P38 | Pre-charge Circuit Voltage Failure |
| | P39 | EEPROM Failure |
| | P40 | AC Input Overvoltage Failure |
| | P41 | Microelectronics Failure |
| | P42 | Compressor Type Code Failure |
| | P43 | Current Sampling Signal Overcurrent |
| Wire controller blinks to cycle through E88 and above codes | | |

4.3 Parameter & Explanation

4.3.1 Running Parameter

| No. | Description | Setting Range | No. | Description | Setting Range |
|-----|--------------------------------|---------------|-----|---|---------------|
| 1 | Compressor Running Frequency | 0~150Hz | 31 | System 2 Compressor Running Frequency | |
| 2 | Fan Running Speed | 0~999Hz | 32 | System 2 Fan Running Speed | |
| 3 | EEV Open Step | 0~480P | 33 | System 2 EEV Open Step | |
| 4 | EVI Valve Open Step | 0~480P | 34 | System 2 EVI Valve Open Step | |
| 5 | AC Input Voltage | 0~500V | 35 | System 2 AC Input Voltage | |
| 6 | AC Input Current | 0~50.0A | 36 | System 2 AC Input Current | |
| 7 | Compressor Phase Current | 0~50.0A | 37 | System 2 Compressor Phase Current | |
| 8 | Compressor IPM Temp. | -40~140℃ | 38 | System 2 Compressor IPM Temp. | |
| 9 | High Pressure Saturation Temp. | -50~200℃ | 39 | System 2 High Pressure Saturation Temp. | |

| No. | Description | Setting Range | No. | Description | Setting Range |
|-----|------------------------------------|---------------|-----|--|---------------|
| 10 | Low Pressure Saturation Temp. | -50~200℃ | 40 | System 2 Low Pressure Saturation Temp. | |
| 11 | Ambient Temp. T7 | -40~140℃ | 41 | System 2 Outer Coil Temp. | |
| 12 | Outer Coil Temp. T1 | -40~140℃ | 42 | System 2 Inner Coil Temp. | |
| 13 | Inner Coil Temp. T4 | -40~140℃ | 43 | System 2 Suction Temp. | |
| 14 | Suction Temp. T2 | -40~140℃ | 44 | System 2 Exhaust Temp. | |
| 15 | Exhaust Temp. T3 | 0~150℃ | 45 | System 2 Economizer Inlet Temp. | |
| 16 | Water Inlet Temp. T8 | -40~140℃ | 46 | System 2 Economizer Outlet Temp. | |
| 17 | Water Outlet Temp. T15 | -40~140℃ | 47 | Reserve | |
| 18 | Economizer Inlet Temp. T5 | -40~140℃ | 48 | Reserve | |
| 19 | Economizer Outlet Temp. T6 | -40~140℃ | 49 | Reserve | |
| 20 | Current Unit Tool Number | 0~120 | 50 | Reserve | |
| 21 | DHW Tank Temp. | -40~140℃ | 51 | Solar Water Heater Temp. | |
| 22 | Plate Heat Exchanger Exhaust Temp. | -40~140℃ | 52 | Zone 2 Temp. | |
| 23 | Driver Manufacturer | 0~10 | 53 | Butter Tank Temp. | |
| 24 | Water Pump Speed PWM | 0~100% | 54 | Total Water Outlet Temp. | |
| 25 | Water Flow | 3~100L/min | 55 | Unit B Phase Input Voltage | |
| 26 | DHW Return Water Temp. | -40~140℃ | 56 | Unit B Phase Input Current | |
| 27 | Unit Input Voltage | 0-500V | 57 | Unit C Phase Input Voltage | |
| 28 | Unit Input Current | 0.00A-99.99A | 58 | Unit C Phase Input Current | |
| 29 | Unit Input Power | 0.00-99.99KW | 59 | Smart Grid Status | |
| 30 | Unit Power Consumption | 0-9999Kw.h | 60 | Zone 2 Mixing Valve Opening | |

4.3.2 Factory Parameter

| No. | Description | Default Value | Setting Range | Note |
|-----|---------------------------------------|---------------|---------------|--|
| L12 | Sterilization | 0 | 0~2 | |
| L13 | Days between Sterilizations | 7 | 5~30 | |
| L14 | Sterilization Start-up Time | 23:00 | 00:00-24:00 | |
| L15 | Sterilization Running Time | 10 | 0-50Min | |
| L16 | Sterilization Temp Setting | 70℃ | 50-80℃ | |
| L22 | DHW return water Setting | 0 | 0~3 | 0-Disable / 1-Continuous return / 2-Cycle return / 3-Temperature |
| L23 | Return Water Temp Setting | 40℃ | 20~65℃ | |
| L24 | Return Water Return Temp Differential | 5℃ | 1~15℃ | |
| L25 | Return Water Interval Period | 30min | 3~90min | |
| L26 | Return Water Running Period | 5min | 1~30min | |
| P03 | Water Flow Switch Setting | 1 | 1~2 | 0-Enable/1-Disable |
| P05 | Linkage Switch Setting | | 0~2 | 0-Enable/1-Disable/2-Thermostatic |

| No. | Description | Default Value | Setting Range | Note |
|------|---|---------------|---------------|---|
| P22 | Ambient temperature value- Unit no starting | -15 | -15~40 | If Ambient Temp. ≤P22 then enter defrost |
| P24 | Ambient temperature value- Allow electric heater to start | 0 | -10~10℃ | |
| P25 | Overprotection value- Inlet and outlet water temperature differential | 0 | -10~10℃ | |
| P26 | Compensation value-Return water temperature | 5 | 0~10℃ | |
| P27 | Floor heating return differential value | 5 | 0~10℃ | |
| P28 | Water Pump Control-Unit shutdown when reaching temperature | 0 | 0~1 | 0-Running /1-Stop /2-Running in cooling mode /3-Running in cooling/heating mode /4-Running in underfloor heating mode |
| P29 | Anti-freeze-water pump running time | 2 | 0~10min | |
| P30 | Defrost mode selection | 0 | 0~2 | 0-Intelligent control /1-Timing control/ 2-Rapid control /3-Dew point control |
| P31 | Defrosting - cumulative runtime | 45 | 0~120 | |
| P32 | Defrosting - coil temperature value | -5 | -30~0 | |
| P33 | Defrosting - temperature differential 1 | 9 | 0~20 | |
| P34 | Defrosting - temperature differential 2 | 7 | 0~20 | |
| P35 | Maximum defrosting time | 10 | 0~30 | |
| P36 | Exit defrosting - coil temperature | 12 | 0~30 | |
| P37 | Shutdown mode - Reaching target temperature | 0 | 0~2 | 0-Intelligent shutdown/1-Temperature shutdown /2-Cooling intelligent |
| P48 | Enable/Disable Hot Water Tank temperature sensor | 0 | 0~1 | 0-Disable/1-Enable |
| P96 | DHW differential value | 5 | 0~10℃ | |
| P99 | Water pump speed regulation temperature differential | 5 | 2~10℃ | |
| P116 | Unit temperature control mode | 0 | 0~1 | 0-Water Inlet Temp./1-Water Outlet Temp. |
| P117 | Ambient temperature - Allow access to anti-freeze | 5 | 0~10℃ | |
| P118 | Outlet water temperature - Allow access to anti-freeze | 3 | 0~20℃ | |
| P139 | Buffer tank electric heating | 0 | 0/1 | 0-Enable/1-Disable/2-AHS |
| P140 | DHW electric heating | | | 0-Enable/1-Disable/2-AHS |
| P150 | Water pump - secondary heating/cooling system | 0/1/2/3 | 2 | |

| No. | Description | Default Value | Setting Range | Note |
|------|---|---------------|---------------|--|
| P151 | Return differential - Hot water heat source | 0-40 | 0 | |
| P152 | Return differential - Heating heat source | 0-40 | 0 | |
| P161 | Auxiliary pump selection | 0/1/2/3/4 | 0 | 0-DHW/1-Cooling/2-Underfloor heating/3-Heating&Cooling/4-Above all |
| P162 | Anti-freezing interval - Hot water pipes | 0~360 | 90 | If set to 0, mean disable |
| P181 | Defrost selection - Evaporate side | 0~2 | 0 | 0-Current/1-Heating/2-DHW |
| P182 | Pipe electric heating option | 0~2 | | 0-3kW+6kW/ 1- 3kW/ 2-6kW/ 3-Disabled |