



Note 1:  
Digital input: %Ix – 1x  
Digital output: %Qx – 0x  
Analog input: %Iwx – 3x  
Analog output: %Qwx – 4x  
Internal memory: %Mx – 0x  
%MWx – 4x

Note 2:  
Digital input: Open/Close  
Digital output: Valve  
Analog input: Level, Flow  
Analog output: Power

Note 3:  
Model:  
Enable : %Mx  
Level, Flow, Power: %MWx

Tank elements:  
- Auto: internal IO  
- Open: internal IO  
- Close: internal IO  
- Open\_st: external IO  
- Close\_st: external IO  
- Enable: external IO  
- Run: external IO  
- Level: external IO  
- Flow: external IO  
- Power: external IO

Auto = 1:  
- Enable = 1  
- Run = 1  
- Enable, Open, Close buttons are disabled.  
Auto = 0:  
- Manually operated

