HIL LIMITED

Reasearch & Development

TEST DATA ON- Kemolit KSV-40(N)

Addressed To : QCD-Faridabad Date Reported :01/12/2022

Source: Wolkem India (kemolit), D.O.S:02.06.2022, Letter Dt:08.07.2022 Ref. No: KEMOLIT-01-2022

Recd. from : Faridabad Plant On: 21/07/2022 SAP Vendor Code : 0 -

Parameter	Std. Value	Test Value
Loss on Ignition (% by mass)	5.0 Max	4.98
CaSiO3 (%)	92 Min	92.4
Moisture content (%)	0.30 Max	0.15
Retention on 200 Mesh (%)	14-20	6.0
Aspect ratio (:)	8.00 Min	8.6
R2O3 (Al2O3 + Fe2O3) (%)	2.50 Max	1.60
Water demand for 100 gm of sample (ml)	45-65	64.8
Sedmentation value (ml)	27.0 Min	28.6
Bulk density (40gms sample) tapped 50 times (g/cc)	1.15 ± 0.15	1.02

Final Remarks - Sample is approved.(Need to discuss about Retention on 200 Mesh (%))

R & D HIL Limited