

Fire NOC in Haryana: a practical guide for industrial buildings

DRAFT FOR REVIEW | GUIDE | B023

Designated reviewer: Atul Goyal. Review pending. PDF prepared 18 September 2026 from the current repository manuscript. This drafting date is not a verified review, approval or source-verification date.

For an industrial building in Haryana, the first fire-approval question is which stage the premises have reached. Approval of the Fire Fighting Scheme addresses the proposed arrangements. The fire safety certificate addresses the completed building and installed measures. An existing certificate also needs to be checked when the building or use changes.

Owners and advisers often use “Fire NOC” as a general term. For an application, use the document name and process required by the competent authority. Haryana's 2022 fire legislation provides the foundation for the distinctions below. [Haryana Fire and Emergency Services Act, 2022, sections 18 to 20](#).

Have a new building, an upcoming renewal or a change to the premises? See Rapid's [Fire Department Permission service](#) for the work we can coordinate. Start the conversation with the building's location, use and current stage.

Start with the building and its actual use

An industrial address alone does not determine the fire requirements. Assemble the building's use, height, floor areas, basements, access and proposed storage or process. Mixed use matters: an office, production hall, storage area and assembly space may create different questions within the same premises.

Section 18 identifies categories requiring scheme approval, including specified high-rise and special buildings. Industrial, storage and hazardous occupancies appear in that framework. The detailed thresholds and building-code provisions need to be applied together. Being below one quoted threshold is not enough to conclude that no fire-safety duty applies.

Give your architect or fire specialist the actual process and materials. “General warehouse” is an inadequate description if the stored goods or storage arrangement carry particular hazards. For [Recycling & Biofuel](#), describe inputs and outputs precisely. For [Commercial & Logistics](#), describe the goods, storage layout and intended movement through the building.

Understand the approval stages

Stage	Question to resolve	Working evidence to organise
Planning	What measures are required for this building and occupancy?	Site facts, building plans, intended use and technical design
Fire Fighting Scheme approval	Has the proposed arrangement received the required approval?	Application, submitted drawings, authority decision and conditions
Completion and certification	Does the completed premises comply with the approved scheme?	Installed-system records, current drawings and inspection responses
Continued use or alteration	Are the system, certificate and actual premises still aligned?	Certificate, maintenance records, changes and renewal requirements

The Act sets out application and inspection for the fire safety certificate after construction and installation. Scheme approval by itself should therefore not be treated as the completed-building certificate.

Prepare a file that reflects the site

Keep the existing building approval, Fire Fighting Scheme approval, certificate and correspondence together. Label drawings by revision and date. Ask the site team to identify any change since the last approved drawing, including internal partitions, mezzanines, exits, storage height or equipment layout.

For a new project, agree how the building designer and fire-system specialist will coordinate access, escape routes, water arrangements and installation space. Procurement should follow the applicable design rather than a generic equipment list. The number and specification of extinguishers, pumps, hydrants or detection devices cannot be decided safely from a blog checklist.

For an operating facility, organise evidence of inspection, testing and maintenance alongside the approval papers. A certificate on file does not make a non-working installation usable in an emergency. The owner and occupier retain responsibilities for the premises under the legislation.

What happens if the site has changed?

Illustrative situation: a warehouse obtained its certificate, then added an internal floor and changed its storage layout. The owner should compare those changes with the approved plans and fire arrangements before relying on the earlier certificate for the revised premises. This is a preparation example, not a legal determination about a particular warehouse.

The Act provides for annual self-declarations and addresses alterations that require a revised scheme. Ask for a specific assessment of the change and required route. Do not describe every alteration as a routine renewal.

Fees, validity and timing

The relevant certificate, building category, current rules and authority instructions govern validity and renewal. Read the dates and conditions on the issued document. Do not assume that a colleague's certificate for another building has the same period or requirements.

Separate authority charges from design, equipment, installation and advisory costs. A quoted processing period should also be separated from the time required to complete drawings, carry out works, resolve deficiencies or provide access for inspection. No adviser controls the authority's decision.

Common questions

Is Fire NOC the same as a fire licence?

The words alone do not establish two separate approvals. Ask which document the requesting party means. Our [Fire NOC and fire licence explanation](#) shows how to identify the actual requirement.

Does a small industrial unit automatically qualify for an exemption?

No automatic conclusion follows from "small" or from MSME registration. The building's occupancy, dimensions, hazards and applicable provisions need to be checked.

Can I use the landlord's certificate?

First check the certificate's premises, covered use, validity and approved layout against your intended occupation. Establish which documents and actions the owner and occupier must provide. A lease does not answer those technical questions.

Is fire approval the only permission needed before occupation?

Other applicable building, occupation, environmental or activity requirements remain separate. See [Building Plan Approval](#) and [Occupation Certificate](#) for those service routes.

Planning safety-equipment investment as well?

Keep the approval work and any financial-assistance assessment separate. If your project includes new safety equipment, our [Safety Compliance Assistance explanation](#) sets out the scheme context and the policy-period checks an investment needs. Do not delay required safety work while waiting for an incentive assessment.

Coordinate the requirement around your facility

Rapid's [Fire Department Permission \(NOC\)](#) service provides the route for discussing the agreed documentation and coordination work. Share the location, use, project stage and any existing approval. [Discuss your project](#) and an expert consultant from Rapid will call you.

[+91 94672 48028](#)

Source links

Links retained from this manuscript. Consult the referenced authority for current requirements; the PDF drafting date does not establish that a source remains current.

1. Haryana Fire and Emergency Services Act, 2022, sections 18 to 20

<https://ulbharyana.gov.in/Website/DirectorateofUrbanLocalBodies/Images/2602b04f-cba9-4fef-b3be-32c9c2629d1a.pdf>