Cambridge Instruments & Engg. Co.

EST. 1963 · HOWRAH, INDIA

RELAY TEST SET · SINGLE PHASE

RTS-5

0–200 A (14 V / 4 V) · 0–240 V A.C. · digital timer

01 KEY SPECIFICATIONS

CURRENT OUTPUT	0–200 A, 8 ranges
VOLTAGE OUTPUT	0–240 V A.C. (alternative)
TIMER	9.999 s (1 ms) / 99.99 s (10 ms)
INPUT	230 V, 1 phase, 50 Hz
METERING	Digital ammeter & voltmeter
DUTY	5 min ON / 10 min OFF



RTS-5 · RELAY TEST SET

02 TECHNICAL SPECIFICATIONS

PARAMETER	SPECIFICATION
INPUT & OUTPUT	
Input	230 V, single phase, 50 Hz A.C.
Current Output	0–1/2/5/10/20A at 14V or 4V; 0–50/100/200A at 4V
Output Voltage (alternative)	0–240 V A.C. at 1 A (mutually exclusive with current)
Fixed Voltages	50 V & 110 V A.C. at 1 A
Duty	Intermittent - 5 min ON / 10 min OFF
Cooling	Air natural
TIMING & METERING	
Timer	9.999 sec (1ms res.) or 99.99 sec (10ms res.)
Ammeter	Rectangular multi-range digital, 0–1/2/5/10/25/50/100/200A
Voltmeter	Rectangular A.C., 0–300 V
GENERAL	
Warranty	12 months against manufacturing defects only

03 APPLICATIONS

- Protective and over-current relay testing
- Earth fault relay testing
- Relay commissioning and maintenance in substations and panels

All specifications are subject to change without prior notice. © Cambridge Instruments & Engg. Co. - RTS-5 Product Catalogue.