



**Cambridge Instruments
& Engg. Co.**

EST. 1963 · HOWRAH, INDIA

OIL TEST SET · TRANSFORMER OIL BDV TESTER

CIE/7050

Transformer oil dielectric strength (BDV) tester up to 50 kV. Manual and motorised variants.

Up to 50kV

CONTINUOUSLY VARIABLE, 500 VA

Manual/Motorised

APPROX. 2KV/SECOND (MOTORISED)

Memory Device

RETAINS BREAKDOWN READING

Transformer Oil BDV Tester

Part of the CIE/7000 Series oil dielectric strength test set range, built for breakdown/withstand voltage testing of transformer and circuit breaker insulating oil per IS 6792:1992 - a cast-resin H.V. transformer with graded insulation, zero-start interlocking, and an interlocked H.T. door cutout for safe operation.

- **0-50kV output** - continuously variable, 500 VA capacity
- **Manual or motorised** - motorised advances at approx. 2kV/second
- **Memory device** - retains breakdown reading after tripping
- **Zero-start interlocking** - plus interlocked H.T. door cutout
- **Analog moving-iron metering** - 96mm² kV meter, L.T. side
- **Standard test vessel** - brass spheres, per IS 6792:1992

Manufactured in India since 1963 - trusted by various State Electricity Boards, Indian Railways, cement and metal industries, and other sectors.



CIE/7050 · OIL TEST SET

01 Full Specification Sheet

PARAMETER	SPECIFICATION
Output Voltage	0-50 kV (continuously variable)
Capacity	500 VA
Input	230 V ±10%, 50 Hz, 1 phase A.C.
Duty	Intermittent
H.V. Winding	Cast-resin, graded insulation, centre point grounded
Metering	96 mm ² A.C. moving-iron voltmeter, L.T. side, scaled in kV (analog)
Motorised Rate	Approx. 2 kV/second (motorised variant)
Test Vessel	Two brass spheres, 12.5-13 mm dia., 4mm or 2.5mm gap, per IS 6792:1992
Warranty	12 months against manufacturing defects

02 CIE/7000 Series - Output Voltage & Capacity

OUTPUT VOLTAGE	CAPACITY	MANUAL MODEL	MOTORISED MODEL
0-50 kV	500 VA	CIE/7050	CIE/7050 MOT
0-60 kV	600 VA	CIE/7060	CIE/7060 MOT
0-70 kV	700 VA	CIE/7070	CIE/7070 MOT
0-75 kV	750 VA	CIE/7075	CIE/7075 MOT
0-80 kV	800 VA	CIE/7080	CIE/7080 MOT
0-90 kV	900 VA	CIE/7090	CIE/7090 MOT
0-100 kV	1000 VA	CIE/7100	CIE/7100 MOT
0-120 kV	1200 VA	CIE/7120	CIE/7120 MOT

03 Typical Applications

- Transformer oil dielectric strength testing before energisation
- Routine oil quality monitoring for distribution and power transformers
- Circuit breaker oil testing
- Power utility and substation maintenance laboratories

04 What's in the Box

- ✓ Instruction manual with circuit diagram
- ✓ Input supply cable, minimum 2 metres, 3-pin plug
- ✓ Test vessel (oil cell) with electrode and gap-setting gauge

05 Optional Accessories

- + Alternate tripping current set point
- + Digital metering in place of analog
- + 2-unit housing
- + Double capacity (20 mA)
- + Magnetic stirrer