Cambridge Instruments & Engg. Co.

EST. 1963 · HOWRAH, INDIA

TECHNICAL CATALOGUE · HAND-DRIVEN · WOODEN BODY

CIE/666

Hand-driven insulation tester in seasoned wood

Direct-reading insulation resistance testing

A compact, portable instrument for direct reading of insulation resistance on electrical operating machines, rotating plant equipment, stationary apparatus, insulation control and switching equipment, distribution networks, communication cables, insulators, transformers, industrial installations, cables, electrical components, wiring and other devices capable of carrying the rated voltage. It is a versatile instrument for locating intermittent shorts, defective electrical connections, insulation failure and conductor failure, and for preventing costly repairs and breakdowns.



CIE/666 · ILLUSTRATIVE IMAGE

01 HIGHLIGHTS

- ✓ Seasoned wooden body with sunmica finish, detachable lid, carrying handle and lock
- ✓ Centrifugal clutch (governor) for constant output voltage
- ✓ Chuck nut locking arrangement prevents anti-clockwise rotation
- ✓ Highly sensitive cross-coil indicator
- ✓ Accurate and quick response: 3 seconds
- ✓ Conforms to IS 2992:1987
- ✓ Silent generator
- ✓ Collapsible driven handle, folds back flush into the casing
- ✓ Wide anti-parallax mirror scale (not provided on triple-range and above)
- ✓ Long life and strength against vibration and impact
- ✓ Guard terminal and externally accessible infinity adjuster on ranges of 1000 MΩ and above

02 TYPICAL APPLICATIONS

- Motors, generators, and other rotating machinery
- Insulation control and switching equipment checks
- Distribution network and communication cable insulation testing
- HV switchgear and transformer insulation testing up to 10,000 V
- Locating intermittent shorts, defective connections, and developing insulation failures

All specifications are subject to change without prior notice. © Cambridge Instruments & Engg. Co. - CIE/666 Technical Catalogue.

03 PRINCIPLE AND CONSTRUCTION

PRINCIPLE

A hand-driven clutch-type A.C. generator and a highly sensitive cross-coil indicator. The generated A.C. voltage is converted to D.C. voltage by silicon diodes.

CONSTRUCTION

Housed in a sturdy, elegant seasoned wooden body with sunmica finish, complete with detachable lid, carrying handle and lock. The instrument is dust-free: rubber shoes hold the surface and give it stability.

04 SALIENT FEATURES

Silent generator

The A.C. generator runs extremely silently and smoothly because of the excellent dynamic balance of its rotating parts, and is free from mechanical noise.

Centrifugal governor

A high-grade centrifugal governor holds the voltage constant for accurate measurement. Variation in crank speed does not affect the reading, as a cut-off clutch disengages the drive beyond the rated speed.

Collapsible handle

The generator driven handle folds back flush into the casing when the tester is not in use.

Quick response

The response time is 3 seconds, when a resistance equal to the central scale mark is suddenly inserted between the measurement terminals, as per IS 2992:1987.

05 PERFORMANCE AND TEST SPECIFICATION

Standard	IS 2992:1987
Indicator	High-sensitivity cross-coil movement; wide anti-parallax mirror scale (not provided on triple-range and above instruments)
Scale length	100 mm (approx.)
Accuracy	Conforms to IS 2992:1987
Generator speed	160 r.p.m. or more; the centrifugal governor holds the output voltage constant
Response time	3 seconds
High voltage test	Withstands minimum 2000 V or (rated voltage + 1000) V A.C. (rms) between the electrical circuit and the handle for one minute
Insulation resistance of the instrument	Better than 50 MΩ at 500 V between the electrical circuit and the containing case

All specifications are subject to change without prior notice. © Cambridge Instruments & Engg. Co. - CIE/666 Technical Catalogue.

06 CONSTRUCTION AND PHYSICAL SPECIFICATION

Guard terminal and infinity adjuster	**Provided on instruments with an insulation range of 1000 MΩ and above**
Body	**Seasoned wooden body with sunmica finish, detachable lid, carrying handle and lock**
Weight	**4.1 kg (approx.)**
Dimensions	**265 × 165 × 185 mm (approx.)**

07 RANGE OPTIONS BY RATED VOLTAGE

Each instrument is built for **one rated voltage** and **one insulation range**. Choose a rated voltage, then **one** range from its row. Ranges are not combined in one instrument unless one of the dual voltage or dual insulation range options below is selected.

RATED VOLTAGE	INSULATION RESISTANCE RANGE (MΩ): ANY ONE OF
100 V	0–20 OR 0–50 OR 0–100
250 V	0–50 OR 0–100 OR 0–250
500 V	0–100 OR 0–200 OR 0–500 OR 0–1000 OR 0–2000
1000 V	0–100 OR 0–200 OR 0–500 OR 0–1000 OR 0–2000
2500 V	0–1000 OR 0–2000 OR 0–2500 OR 0–5000 OR 0–10,000 OR 0–20,000 OR 50–50,000
5000 V	0–5000 OR 0–10,000 OR 0–20,000 OR 50–50,000 OR 100–100,000
10,000 V	0–10,000 OR 0–20,000 OR 50–50,000 OR 100–100,000

Any other range can be manufactured against specific requirements.

08 DUAL VOLTAGE AND DUAL INSULATION RANGE OPTIONS

Dual voltage and dual insulation range

One instrument with two rated voltages, each with its own insulation range, selected by a switch. The selected range must be within the rated resistance listed for that voltage (voltage to measurable insulation range ratio up to 1:2 only; for any other ratio, please check with us). Not available for the 10,000 V instrument.

Single voltage but dual insulation range

One rated voltage with two insulation ranges. The selected ranges must be within the rated resistance listed for that voltage. Not available for the 10,000 V instrument.

Continuity range (in 500 V and 1000 V only)

Available as an extra on single-voltage, single-range instruments, or on dual-voltage, dual-range instruments.

All specifications are subject to change without prior notice. © Cambridge Instruments & Engg. Co. - CIE/666 Technical Catalogue.

09 MULTIRANGE INSULATION TESTER (HAND-DRIVEN): CIE/666/MR

SERIES	RATED VOLTAGE / INSULATION RANGE (MΩ)	CONTINUITY
MR-1	1000 V / 0–2000 500 V / 0–1000 250 V / 0–500	0–20 kΩ
MR-2	1000 V / 0–200 500 V / 0–100 250 V / 0–50	0–1 kΩ
MR-3	500 V / 0–1000 250 V / 0–500 100 V / 0–200	0–5 kΩ
MR-4	500 V / 0–100 250 V / 0–50 100 V / 0–20	0–1 kΩ
MR-5	2500 V / 0–5000 1000 V / 0–2000 500 V / 0–1000	0–20 kΩ
MR-6	2500 V / 0–1000 1000 V / 0–200 500 V / 0–100	0–1 kΩ
MR-7	5000 V / 0–20,000 2500 V / 0–10,000	0–20 kΩ
MR-8	5000 V / 0–5000 2500 V / 0–2500	0–5 kΩ

Multirange instruments are provided with a range selector switch, so one instrument covers every voltage and range listed in its series. Anti-parallax mirror scale is not provided on triple-range and above instruments. Any other range can be manufactured against specific requirements.

10 OPTIONAL ACCESSORIES (AT EXTRA COST)

- Carrying case
- Testing leads, 1 m or 2 m (up to 1000 V)
- H.V. testing leads, 2 m (general / special)

11 HOW TO ORDER

To order, quote the **model**, the **rated voltage** and the **insulation range**, for example **CIE/666, 500 V / 0–2000 MΩ**. Any range not listed can be manufactured against specific requirements.

All specifications are subject to change without prior notice. © Cambridge Instruments & Engg. Co. - CIE/666 Technical Catalogue.