Cambridge Instruments
& Engg. Co.

EST. 1963 · HOWRAH, INDIA

RELAY TEST SET · THREE PHASE

RTS-33

3-phase · 0–360° phase angle · 0–50 A · 415 V input

0–360°
PHASE ANGLE, COARSE + FINE CONTROL

0–50A
5 CONTINUOUSLY VARIABLE TAPS

415V, 3-Phase
INPUT, 250 VA BURDEN

01 KEY SPECIFICATIONS

PHASE ANGLE	0–360°, coarse 60° + fine ±30°
TEST CURRENT	0–50 A, 5 taps
TIMER	0–9.999 s / 0–99.99 s
INPUT	415 V, 3 phase, 50 Hz
FIXED DC	30 / 110 / 220 V
CONSTRUCTION	Two-unit system



RTS-33 · RELAY TEST SET

02 TECHNICAL SPECIFICATIONS

PARAMETER	SPECIFICATION
INPUT & OUTPUT	
Input	415 V ±10%, 3 phase, 4 wire, 50 Hz A.C.
Burden	250 VA (current and voltage circuits)
Test Current Taps	0–1/5/10/25/50A (0–100% regulation per tap)
Duty	Continuous up to 10A; 25A & 50A: intermittent (5 min ON, 10 min OFF)
Test Voltage	0–110% of 110V ph-ph (63.5V ph-N), 3-phase, continuously variable
Fixed DC Voltage	Isolated 30V / 110V / 220V at 100 VA, available for 30 min
PHASE & TIMING	
Phase Angle	0–360° - coarse 60° steps + fine ±30° (Unit 2, static phase-shifter)
Phase Angle Meter	360° range, 1° resolution
Time Measurement	0–9.999 sec (0.001s res.) and 0–99.99 sec (0.01s res.)
METERING	
Current Metering	CT-operated ammeter per phase, 0–1A, 0–100% scaled, ±1% accuracy
Voltage Metering	0–200V, ±1% accuracy, 0.1V resolution, phase selector
GENERAL	
Construction	Two-unit system; 1m interconnection cable; 4-core 5m mains cable
Warranty	12 months against manufacturing defects

03 APPLICATIONS

- Distance relay commissioning
- Directional and differential protection relay testing
- Over-current, earth fault, over/under-voltage relay testing
- Phase-to-phase fault simulation
- Indian Railways traction protection relay testing

04 WHAT'S IN THE BOX

- ✓ Operation manual
- ✓ Schematic circuit diagram
- ✓ Works test report
- ✓ 1m interconnection cable (Unit 1 to Unit 2)
- ✓ 4-core, 5m mains input cable

All specifications are subject to change without prior notice. © Cambridge Instruments & Engg. Co. - RTS-33 Product Catalogue.