

# OpenBuildingControl

—

Team meeting

Michael Wetter

Philip Haves

Jianjun Hu

Milica Grahovac

November 15, 2018



**Lawrence Berkeley National Laboratory**

# Upcoming deadlines

By Q6, demonstrate with an actual measured control response that the controls verification can signal satisfied, undecided, and violated test results.

—

By Q7, release a version of the control library for primary systems, facade and lighting in Modelica on <http://github.org/lbl-srg/modelica-buildings>.

By Q7, release first version of the controls verification test module.

By Q8, release case study report.

By Q8, demonstrate importing and exporting CDL in the control design tool.


Todo: Render connections that overlap or connect to the same input/output.

By Q8, write first version of commercialization and market transformation plan with the goal to show value and obtain commitment from large owners and design firms for the process.


# Verification test with a measured control response - Sequence specification

We validated a **trended output** of a control sequence that defines the **cooling coil valve** position.

The cooling coil valve sequence is a part of the ALC EIKON control logic implemented in building 33 at LBNL.



ALC EIKON specification



CDL specification

# Verification test with a measured control response - ALC EIKON parameter collection

We recorded ALC EIKON sequence parameters and input trends with a 5s interval:

- Supply air temperature [F]
- Supply air temperature setpoint [F]
- Outdoor air temperature [F]
- VFD fan enable status [0/1]
- VFD fan feedback [%]




ALC outdoor air temperature  
hysteresis to enable/disable  
the controller



ALC PI controller parameters


# Verification test with a measured control response - Conducting the verification




Modelica model that conducts the verification

# Verification test with a measured control response - Verification results


**Trended input signals**




**Cooling valve control signal: reference trend vs. modeled result**



**Modeled result/recorded trend correlation**




# Verification test with a measured control response - Verification results using the funnel tool



# Primary sequence implementation I



- Developed a typical plant control schematics and sequences based on “ASHRAE Fundamentals of Chilled Water Plant Design and Control SDL, Chapter 7. Controls”:
  - 2 chillers, 2 CT, 2 CHWP, 2 CWP



- Included water side economizer in the package




# Primary sequence implementation II



Next steps:

- Comply with latest ASHRAE RP-1711 primary sequences document
- Create top level user facing controllers
- Review the package and include in the library




# Case study I

Chiller plant in a commercial office building in Hacienda Business Park in Pleasanton, California

Control design by Taylor Engineering

Plant consists of:

- 2 x 310 ton screw chillers
- 2 x CWP, CHP
- 2 x CT
- 1 x WS economizer HE




## Trend data specs

- ~50 data points
- 1 minute interval data for Jun 22 - July 10 2018
- 5 minute interval data for Mar 11 - Jun 2 2018
- multiple operation stages

## Eikon equipment view

# Case study II

## Plant schematics with a WSE




# Case study III

## Approach

- Introduce case study specific edits to primary sequences
- Pick a sequence for conducting the verification test (e.g. WSE control)
- Implement sequence verification with trended data. The method is the same as used for the cooling valve verification example

*Only one sequence or whole plant control?*

ALC EIKON  
implementation of the  
WSE sequence



# Sequence translation tool

“modelica-json”: parse control sequences written in Modelica to JSON, and from JSON to other format, such as html, to graphical rendering

— different parsing modes:

- “cdl”: ensure models following cdl syntax
- “modelica”: general modelica syntax

— graphical annotation

- provide graphical layout for display in block diagram editors (Modelica or actual control platforms)
- generate graphical diagram for inclusion in documentation (in svg format)
- render both icon and diagram layer

```
block CustomPWithLimiter
  "Custom implementation of a P controller with variable output limiter"

  parameter Real k = 2 "Constant gain";

  Buildings.Controls.OBC.CDL.Interfaces.RealInput yMax "Maximum value of output"
  annotation (Placement(transformation(extent={{-140,20},{-100,60}})));

  Buildings.Controls.OBC.CDL.Interfaces.RealInput e "Control error"
  annotation (Placement(transformation(extent={{-140,-60},{-100,-20}})));

  Buildings.Controls.OBC.CDL.Interfaces.RealOutput y "Control signal"
  annotation (Placement(transformation(extent={{100,-10},{120,10}})));

  Buildings.Controls.OBC.CDL.Continuous.Gain gain(final k=k) "Constant gain"
  annotation (Placement(transformation(extent={{-60,-50},{-40,-30}})));

  Buildings.Controls.OBC.CDL.Continuous.Min minValue "Outputs the minimum of"
  annotation (Placement(transformation(extent={{20,-10},{40,10}})));

equation
  connect(yMax, minValue.u1) annotation (
    Line(points={{-120,40},{-120,40},{-20,40},{-20,6},{18,6}},
      color={0,0,127}));
  connect(e, gain.u) annotation (
    Line(points={{-120,-40},{-92,-40},{-62,-40}},
      color={0,0,127}));
  connect(gain.y, minValue.u2) annotation (
    Line(points={{-39,-40},{-20,-40},{-20,-6},{18,-6}},
      color={0,0,127}));
  connect(minValue.y, y) annotation (
    Line(points={{41,0},{110,0}},
      color={0,0,127}));

  annotation (Documentation(info="<html>
  <p>
    Block that outputs y = min(yMax, k*e),
    where
    yMax and e are real-valued input signals and
    "
```

### 1. FromModelica.CustomPWithLimiter

Custom implementation of a P controller with variable output limiter

#### 1.1. Info

Block that outputs  $y = \min(yMax, k \cdot e)$ , where  $yMax$  and  $e$  are real-valued inputs

#### 1.2. Parameters



It has the following parameters:

Name	Description	Value	Unit	Display unit	Type	min	max
General							
Parameters							
k	Constant gain	2			Real		

#### 1.3. Inputs

It has the following inputs:

Type	Name	Description	min	max	Unit
Real	yMax	Maximum value of output signal			
Real	e	Control error			



Update about commercialization plan (separate slides)