

 SPARTAN CONTROLS		AMBIENT TEMP		-40°C TO 50°C	
		CERTIFIED TO CSA STD C22.2 #286, #213		ENCL. RATING	TYPE 4X
PRODUCTION #	TBD				
SERIAL #	TBD				
VOLTAGE	120VAC	AMPS	20/CCT		
WIRE		FREQ	SCCR		
CLASS	1	DIV	2	GROUP	B,C,D
DATE				TEMP	T3

DETAIL "ETL_13"

WARNING

MAY CONTAIN MORE THAN ONE LIVE CIRCUIT (SEE WIRING DIAGRAM).

ALL EQUIPMENT IN THIS PANEL MUST BE SUITABLE FOR USE IN CLASS I DIVISION 2 / ZONE 2 HAZARDOUS AREAS; SUBSTITUTION OF EQUIPMENT MAY IMPAIR SUITABILITY.

REPLACE FUSES WITH SAME TYPE AND RATING. USE OF APPROVED FUSES IS REQUIRED; DO NOT EXCEED FUSE RATINGS.

ENSURE NO GAS PRESENT AND DISCONNECT POWER BEFORE SERVICING, OPERATING DISCONNECT TERMINALS / TEST JUMPERS AND/OR REMOVING FUSES.

AUTHORIZED PERSONNEL ONLY

AVERTISSEMENT

PEUT CONTENIR PLUS D'UN CIRCUIT SOUS TENSION (VOIR SCHÉMA).

TOUT LES ÉQUIPEMENTS INSTALLÉS DANS CE PANNEAU DOIVENT ÊTRE ADAPTÉS À CLASSE I DIVISION 2 / ZONES DANGEREUSES.


LA SUBSTITUTION DE COMPOSANTS PEUT RENDRE CE MATÉRIEL INACCEPTABLE. LES FUSIBLES DE REMPLACEMENT DOIVENT ÊTRE DE MÊME TYPE ET DE MÊME CAPACITÉ NOMINALE QUE LES FUSIBLES D'ORIGINE.

L'UTILISATION DE FUSIBLES APPROUVÉES EST REQUISE.

NE PAS DÉPASSER LE CALIBRE DES FUSIBLES. S'ASSURER DE L'ABSENCE DE GAZ ET COUPER L'ALIMENTATION AVANT L'ENTRETIEN ET LE DÉPANNAGE, BORNES D'EXPLOITATION DÉCONNECTÉES, CAVALIERS DE MESURE ET / OU LE RETRAIT DES FUSIBLES.

PERSONNEL AUTORISÉ SEULEMENT

DETAIL "2B"



DETAIL 9

PANEL NAME	PRODUCTION #	SERIAL #

TAGNAME	SIZE	FONT TYPE & SIZE	COLOUR (LTR/BKG)	LINE1	LINE2	LINE3
A1	4" [101mm]H X 9" [228mm]W	SWISS721 BT, 3/4" [19.1mm]H (72 PT)	BLK / WHT	SEE TABLE	FOR PANEL NAME	
B2	5 3/4" [146mm]H X 5 1/2" [140mm]W	**SEE DETAIL 2B	WHT / RED			
C1	4" [102mm]H X 4" [102mm]W	**SEE DETAIL ETL_13	BLK / WHT			
D1	1" [25mm]H X 2" [51mm]W	SWISS721 BT, 3/16" [4.8mm]H (16 PT)	BLK / WHT	CHASSIS	GROUND BAR	CGB
E1	1" [25mm]H X 2" [51mm]W	SWISS721 BT, 3/16" [4.8mm]H (16 PT)	BLK / WHT	DC	GROUND BAR	DCGB
F1	1" [25mm]H X 2" [51mm]W	SWISS721 BT, 3/16" [4.8mm]H (16 PT)	BLK / WHT	FIELD CABLE	GROUND BAR	FCGB
G1	1" [25mm]H X 2" [51mm]W	SWISS721 BT, 3/16" [4.8mm]H (16 PT)	BLK / WHT	CIOC1		
H1	2" [51mm]H X 2" [51mm]W	SWISS721 BT, 1/4" [6.4mm]H (24 PT)	BLK / WHT	SPARE	FUSES	
T1	1" [25mm]H X 2" [51mm]W	SWISS721 BT, 3/16" [4.8mm]H (16 PT)	BLK / WHT	RTD		
AB	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	ACSP1		
AC	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	ACSP2		
AD	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	120VAC	UPS	
AE	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	120VAC	REGULAR1	
BB	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	DCTS1		
BC	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	DCTS2		
BD	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	DCTS3		
BE	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	DCTS4		
BF	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	DCTS5		
CA	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	24PS1		
CB	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	24PS2		
CC	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	RM1		
EA	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	TS-SOV		
EB	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	TS1		
EC	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	ESDTS1		
FA	1/2" [13mm]H X 3 5/8" [93mm]W	SWISS721 BT 1/8" [3.2mm]H (12PT)	BLK / WHT	CIOC1-BP1		
FB	1/2" [13mm]H X 3 5/8" [93mm]W	SWISS721 BT 1/8" [3.2mm]H (12PT)	BLK / WHT	CIOC1-BP2		
FC	1/2" [13mm]H X 3 5/8" [93mm]W	SWISS721 BT 1/8" [3.2mm]H (12PT)	BLK / WHT	CIOC1-BP3		
FD	1/2" [13mm]H X 3 5/8" [93mm]W	SWISS721 BT 1/8" [3.2mm]H (12PT)	BLK / WHT	CIOC1-GATEWAY		
FE	1/2" [13mm]H X 3 5/8" [93mm]W	SWISS721 BT 1/8" [3.2mm]H (12PT)	BLK / WHT	CIOC1-T		
GA	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	ALARMS		
GC	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	FOPP1		
GD	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	TPSW1		
LA	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	LGTR1		
LB	5/16" [8mm]H X 1 5/16" [33mm]W, WAD	SWISS721 BT, 3/32" [2.3mm]H (10PT)	BLK / WHT	ESDR1		

FONT PROPERTIES
SWISS721 HV BT 24PT
SWISS721 BT 10PT
SWISS721 BT 14PT
SWISS721 HV BT 20PT
SWISS721 BT 10PT
SWISS721 BT 14PT

SHOP NOTES:

1. ALL ITEMS ON THIS MODULE (EXCLUDING MANUAL VALVES) INCLUDE THE TAG PREFIX PRD0154.

ENGINEERING NOTES:

1. THIS DRAWING REFERENCES THE ENGINEERING RECORD G02-1-PRDXXXX-E-RIO-01-P01-05 REV 0 FOR ALL TECHNICAL INFORMATION. IN THE EVENT OF DISCREPANCY BETWEEN THIS DRAWING AND THE ENGINEERED DRAWING OF RECORD, THE ENGINEERED DRAWING OF RECORD WILL TAKE PRECEDENCE UNLESS THE CHANGE IS PROPERLY CLOUDED AS A REVISION TO THIS DRAWING AND STAMPED BY A PROFESSIONAL ENGINEER.

[illegible]

REDRAWN FROM SPARTAN
VENDOR DRAWING PACKAGE
DV-54809-ZX-210-00 REV 0