Cover Letter

A Lightweight Earthquake Early Warning Pipeline and Its Evaluation on Three Seismic Networks

H. Oğuz Bolat,Sibel Çimen,Bülent Bolat,Tülay Yıldırım

Dear Editors-in-Chief,

Please find enclosed the manuscript “A Lightweight Earthquake Early Warning Pipeline and Its Evaluation on Three Seismic Networks”, which we submit for exclusive consideration as a research article in Computers & Geosciences. We confirm that the submission follows the journal’s requirements and includes every item of its submission checklist.

The manuscript addresses both of the journal’s scopes. Computationally, it presents ayzek, a self-contained C++23 pipeline for the detection stage of earthquake early warning that also reports a P-wave displacement magnitude. Its hand-written inference reproduces the PyTorch networks to within floating-point rounding, its replays of archived data are deterministic, and the same build runs on a Raspberry Pi 4. It also presents a replay protocol, implemented as a reproducible workflow, that measures detectors at their operating point with chance correction, paired tests and catalog-quiet data, whose settings, including the baselines’, were fixed in a public, timestamped release before any test waveform was fetched. Geoscientifically, it measures how a learned detector, two classical triggers and two published models behave on continuous records of three networks under that protocol: the Greek networks served by the National Observatory of Athens and New Zealand’s GeoNet, which no model had seen, and the Turkish KO network the detector was trained on, held out in time. At the settings matched on unmatched alarms the learned detector detected 22.4 more chance-corrected events than STA/LTA of 177 on the Greek sequences, though with twice its unmatched alarms, and 18.1 more of 151 on the New Zealand sequences, with equal unmatched alarms; the KO test, under its target in its two-month pool, was not significant. Causal PhaseNet was equivalent to the learned detector on both unseen networks. On New Zealand’s catalog-quiet windows the learned detector raised a fraction of the classical detectors’ alarms; on Greece it did not, and an exploratory analysis traces half of its quiet-window alarms to one station’s emergent noise that STA/LTA ignores. On a 728-day record, two detectors with nearly equal ROC-AUC differed by a factor of 1.6 in recall at one false alarm per day.

The source code, model weights, the protocol and the test settings, and the reproduction scripts are in a public repository under the GNU General Public License, archived on Zenodo, with the details listed in the section “Code availability”. The test waveforms are open at their data centers and are not redistributed; the released request records and file hashes let anyone fetch and check the same data. The AFAD development waveforms cannot be redistributed, and public KOERI datasets reproduce the development results.

The use of generative AI tools during this work is declared in the manuscript, and the authors reviewed and edited all content and take full responsibility for it. The manuscript has not been published and is not under consideration elsewhere, all authors approve its submission, and they declare no competing interests.

Sincerely,

H. Oğuz Bolat, on behalf of the authors
Department of Geomatics Engineering, Yıldız Technical University, Davutpaşa Campus, 34220 Esenler, İstanbul, Türkiye
oguz.bolat@std.yildiz.edu.tr

Highlights

A Lightweight Earthquake Early Warning Pipeline and Its Evaluation on Three Seismic Networks

H. Oğuz Bolat,Sibel Çimen,Bülent Bolat,Tülay Yıldırım

- Self-contained C++ detection pipeline reproduces PyTorch networks to rounding
- Method and baselines fixed in a timestamped release before any test data
- Learned detector found 18 and 22 more events than STA/LTA on two unseen networks
- Quiet-data alarm rates of all detectors measured per network at equal alarms
- Causal PhaseNet was equivalent to the learned detector on both unseen networks

A Lightweight Earthquake Early Warning Pipeline and Its Evaluation on Three Seismic Networks

H. Oğuz Bolat[a,*], Sibel Çimen[b], Bülent Bolat[b] and Tülay Yıldırım[b]

[a]Department of Geomatics Engineering, Yıldız Technical University, Davutpaşa Campus, 34220 Esenler, İstanbul, Türkiye
[b]Department of Electronics and Communication Engineering, Yıldız Technical University, Davutpaşa Campus, 34220 Esenler, İstanbul, Türkiye

ARTICLE INFO

Keywords:
Earthquake early warning
Seismic event detection
Deep learning
Real-time processing
False alarms
Replay testing
Pre-registration

ABSTRACT

Earthquake early-warning detectors run continuously, where false alarms accumulate, yet learned detectors are typically evaluated on curated windows or tuned on the records they are tested on. We present ayzek, a lightweight, self-contained C++23 detection pipeline whose networks reproduce their PyTorch counterparts to within rounding and whose replays are deterministic, and a replay protocol that measures detectors at their operating point with chance correction, paired tests and catalog-quiet data. All settings of the method and of its baselines were chosen on Turkish development data and fixed in a timestamped release before testing on three networks: the Greek networks and New Zealand's GeoNet, unseen by any model, and the KOERI network, held out in time. The learned detector is compared with a short-term average/long-term average (STA/LTA) trigger, FilterPicker, EQTransformer and PhaseNet in the same pipeline. At the settings matched on unmatched alarms, it detected 150.3 of 177 Greek events after chance correction against 127.9 for STA/LTA (difference 22.4, 95% interval 11.7–33.5), though with 371 unmatched alarms against 189, and 84.2 of 151 New Zealand events against 66.1 (18.1, 7.2–29.5); KOERI's two-month pool held 36 events, a difference of 2.5 (−0.5 to 5.9). Causal PhaseNet was equivalent to it on both unseen networks. On catalog-quiet data it raised 0.9 alarms per day against 1.6 for STA/LTA on New Zealand, but 19.3 against 20.7 on Greece, half from one noisy station. Each alarm carries a P-wave displacement magnitude. The pipeline runs on a Raspberry Pi 4; code and protocol are open.

1. Introduction

Earthquake early warning (EEW) systems run a detector continuously on every station, and the P travel time to the stations needed to declare an event bounds the warning they can give (Allen et al., 2009). Over hours without seismicity, the detector's false alarms accumulate. Learned detectors, however, are typically evaluated on curated windows with balanced classes, where a metric such as the area under the receiver operating characteristic curve (ROC-AUC) says little about the false-alarm rate at the operating point. When a detector is evaluated on continuous records, it and its baselines are usually tuned on records from the same network and period.

The computational contribution of this study is twofold. The first is ayzek, a lightweight, self-contained C++23 pipeline from miniSEED decoding to the network alarm and a first magnitude, with hand-written inference and no machine-learning runtime, verified against its PyTorch models, deterministic in replay, and running unchanged on a Raspberry Pi 4. The second is a replay protocol, implemented as a reproducible workflow, that measures detection at the operating point. Chance matches with the catalog are corrected by shifting the catalog in time, only the stations that

*Corresponding author
oguz.bolat@std.yildiz.edu.tr (H.O. Bolat)
ORCID(s): 0009-0000-8522-7746 (H.O. Bolat); 0000-0003-3790-7362 (S. Çimen); 0000-0002-2468-8618 (B. Bolat); 0000-0001-9993-5583 (T. Yıldırım)

raised an alarm are matched, detectors are compared with paired tests, and false alarms are counted on data without cataloged seismicity. Every setting of the detector and of the baselines was chosen on development data by rules stated in advance, and the whole method, the selection rules for the test data and the endpoints were then committed to a public release and timestamped before any test waveform was fetched.

The geoscientific contribution is a measurement of how learned and classical detectors behave on continuous seismic records from three networks under that protocol: the five Greek networks served by the National Observatory of Athens and the New Zealand national network, neither used in training, and the Turkish KO network on which the detector was trained, held out in time. The pipeline's learned detector is compared with a recursive STA/LTA trigger, FilterPicker (Lomax et al., 2012) and the published EQTransformer (Mousavi et al., 2020) and PhaseNet (Zhu and Beroza, 2019) models, to test whether any gain over the classical trigger is specific to our detector. In this study an alarm is a network detection with a first magnitude rather than a warning that an operational system could issue, and all results come from replays of archived data. The study asks whether the advantage of a learned detector over classical triggers, measured on development data, survives on networks it has not seen, at equal false-alarm rates, under a comparison fixed in advance.

2. Background

Public EEW systems share a design: a telemetered network, a pipeline that detects and characterizes the event from the first seconds of P waves, and an alert policy. Japan's nationwide system has run since 2007 on point-source estimates from the stations nearest the hypocenter (Hoshiba et al., 2008), joined in 2018 by PLUM, which propagates observed shaking instead of a source (Kodera et al., 2020). Taiwan's reports an event within 20 s from a strong-motion network (Hsiao et al., 2009) densified by low-cost MEMS sensors (Wu et al., 2013). ShakeAlert's EPIC and FinDer were tested on a replay platform before public rollout (Kohler et al., 2018; Cochran et al., 2018; Chung et al., 2019; Kohler et al., 2020); Mexico's SASMEX has alerted for thirty years (Suárez, 2022); Israel's TRUAA (Nof and Kurzon, 2021) and Istanbul's threshold-based system (Alcik et al., 2009) are regional examples. In Europe, PRESTo (Zollo et al., 2009) is a free regional platform, tested on Greek Ionian stations (Bracale et al., 2021), and the Virtual Seismologist and FinDer run as modules of the SeisComP monitoring framework (Behr et al., 2016; Massin et al., 2021; Porras et al., 2021); EPIC has been replayed on Turkish data (Tunç et al., 2024; Marcou et al., 2025; Budakolu et al., 2026). Meier et al. (2020) ran PLUM, EPIC and FinDer on 219 Japanese earthquakes with common scoring, the closest precedent to the replay comparisons of this study. Low-cost designs move processing toward the sensor, from fixed smartphones with a cloud back end (Brooks et al., 2021) to PLUM on Raspberry Shake nodes (Prasanna et al., 2022); deep-learning workflows such as QuakeFlow (Zhu et al., 2023) and single-station models such as CREIME (Chakraborty et al., 2022) run under Python runtimes, offline or in the cloud. All of these detect with amplitude or

picker triggers, or with learned models that need a runtime, inside a hosting framework. The pipeline of this study differs in both respects: the station stage is a learned detector with hand-written inference in one binary that runs on a single-board computer, and the whole pipeline, with its classical and published baselines, is evaluated by replay under a comparison fixed before the test data were chosen.

Classical triggers such as the ratio of short- to long-term averages (Allen, 1978; Withers et al., 1998) and multi-band pickers such as FilterPicker (Lomax et al., 2012) are inexpensive and time an onset to the sample, but an amplitude criterion sensitive enough for small earthquakes also fires on impulsive cultural and instrumental transients. Deep networks trained to detect earthquakes (Perol et al., 2018; Ross et al., 2018; Mousavi et al., 2019b) and to pick phases (Zhu and Beroza, 2019; Mousavi et al., 2020) are mostly evaluated on curated windows, as the standardized datasets (Mousavi et al., 2019a) and model collections (Woollam et al., 2022) encourage, although learned pickers do run on continuous data (Mousavi et al., 2020; Yeck et al., 2021) and transfer well between regions at similar distances (Münchmeyer et al., 2022). Comparisons of detectors at a fixed alarm budget on continuous records remain rare, and rarer still with false alarms measured on catalog-quiet data and the method fixed before the test data were seen. ROC-AUC is insensitive to class prevalence (Fawcett, 2006), which precision–recall analysis (Davis and Goadrich, 2006; Saito and Rehmsmeier, 2015) and partial areas at low false positive rates (McClish, 1989) address; in seismic detection the operating region is extreme, one window false alarm per day among 172 800 decisions per station and day being a false positive rate below 10^{-5}.

3. Material and methods

3.1. Development and test data

All choices in this study were made on development data; the test results come from data that none of these choices used, with one exception, the per-station STA/LTA ratios of Section 3.6. The learned detector was trained on 6 s three-component windows from 181 stations of the KO (Kandilli Observatory and Earthquake Research Institute (KOERI), Boğaziçi University, 1971), 6G (Kandilli Observatory and Earthquake Research Institute (KOERI), Boğaziçi University, 2013b) and IJ (Kandilli Observatory and Earthquake Research Institute (KOERI), Boğaziçi University, 2013a) networks of the Kandilli Observatory and Earthquake Research Institute (KOERI), around cataloged events of $M \geq 2$ up to 29 August 2026, partitioned by station into training, validation and test sets (Section S19). The development replays (Table 1, Figure 1) come from the continuous archive of broadband stations of the Turkish National Seismic Network (TU; Disaster and Emergency Management Authority (AFAD), 1990), operated by the Disaster and Emergency Management Authority (AFAD) in the Marmara and northern Aegean regions and absent from the training set. With three public KOERI sets, they comprise two tuning windows, two sequences and 23 quiet windows (102.8 h). One KOERI set overlaps the detector's training data and serves as a demonstration only. Events are scored only at

stations where they are visible, with the signal-to-noise ratio of the 2–20 Hz vertical component around the IASP91 P arrival t_P (times in seconds),

$$\mathrm{SNR} = \mathrm{RMS}\big(x[t_P - 1,\ t_P + 12]\big)/\mathrm{RMS}\big(x[t_P - 60,\ t_P - 10]\big), \tag{1}$$

of at least 3.

Table 1
Development replays. All settings of this study were chosen on them, and no test result comes from them.

Dataset	Network	Start (UTC)	Duration	Stations	Catalog events	Role
Sındırgı	TU	2025-11-10 18:04:04	30 min	3	9	tuning
Marmara Sea	TU	2025-04-23 08:29:01	3 h	8	57	tuning
Sındırgı M_w 6.1	TU	2025-08-10 16:00	3 h	6	66	tuning (baselines)
Simav M_w 4.8	TU	2026-04-11 14:00	3 h	6	56	tuning (baselines)
Quiet windows (23)	TU	2024-05-22 to 2025-03-07	102.8 h	7–8	0	alarm rate
Quiet window	KO	2024-01-03 11:25:00	5.8 h	6	0	alarm rate, public
Sındırgı M_w 4.9	KO	2025-11-10 18:04:00	31 min	6	9	tuning (baselines), public
Marmara M_w 6.2	KO	2025-04-23 09:00:00	1 h 45 min	8	37	demonstration, public

Note. Catalog events are counted within 250 km of the station centroid. The learned detector's trigger rule was chosen on the first two replays; the baselines' final settings on the four event sequences and the KO M_w 4.9 window (Section 3.6). The two AFAD sequences and the quiet windows also served, before the release date, as this study's development test bed (Section S20). Stations are listed in Table S1; of 15 KO stations, 11 contributed training or validation windows.

The tests use three networks, each reported separately and not pooled (Table 2, Figure 2): the Greek networks HL (National Observatory of Athens, Institute of Geodynamics, Athens, 1975), HT (Aristotle University of Thessaloniki, 1981), HA (University of Athens, 2008), HP (University of Patras, 2000) and HC (Technological Educational Institute of Crete, 2006), served by one EIDA node; the New Zealand network NZ (GNS Science, 2021); and KO (Kandilli Observatory and Earthquake Research Institute (KOERI), Boğaziçi University, 1971), the network the detector was trained on, held out in time from 30 August 2026, after the last training window of any model. Of the Greek and New Zealand data, only four 6 h windows per network from before the test period were used, to set the per-station STA/LTA ratios.

A station is used if it records three HH channels at 100 Hz with at least 90% coverage of the test period, checked before any waveform was fetched, and its components can be rotated to north and east; coordinates and gains come from each network's StationXML (Table 2).

Sequences. Each network's test pool holds all events of $M \geq 4.5$ in its catalog within its test period that have at least five usable stations within 150 km; the catalogs are EMSC's (European-Mediterranean Seismological Centre (EMSC),




Figure 1: The development data: TU stations of the AFAD archive, KO stations of the public KOERI sets, the largest event of each replayed sequence, and the area within 250 km of the quiet-window stations, in which no cataloged event may lie during a quiet window. Relief from ETOPO 2022 (NOAA National Centers for Environmental Information, 2022).

2026) for KO, NOA's for Greece and GeoNet's (GNS Science, 1970) for New Zealand. In time order, each such event starts a sequence unless it lies within 3 h after the first event of an earlier sequence with which its stations share at least one; it then belongs to that sequence. A sequence is replayed for 3 h from 10 min before its first event on its nearest usable stations within 150 km, at most eight and at least five, and its cataloged events within 250 km of the stations' centroid are scored as on the development data. The test periods end at the release date (2026-10-30 12:55:36 UTC). Each sequence is assigned, in time order, to this study or to a reserve for later tests by a pseudo-random draw (seed 42). This study's sequences are taken in time order until their scorable cataloged events, counted from the catalog before

Table 2
Test networks, each reported separately.

Group	Networks (operator)	Data center	Catalog	Period from	Target	Stations usable / probed
Greece	HL (NOA), HT (AUTH), HA (University of Athens), HP (University of Patras), HC (Crete)	NOA EIDA node	NOA	2023-01-01	150	81 / 200
New Zealand	NZ (GeoNet)	GeoNet	GeoNet	2023-01-01	150	36 / 134
KO	KO (KOERI)	KOERI EIDA node	EMSC	2026-08-30	240	123 / 155

Note. All test periods end at the release date, 2026-10-30 12:55:36 UTC. Target: scorable cataloged events of this study's sequences (Section 3.6). Stations: usable over the test period (three HH channels at 100 Hz, at least 90% coverage, rotatable components) out of those probed, determined from the availability listings when the sequences were selected, after the release date. For New Zealand the listing is the day files of GeoNet's open-data bucket, which bound coverage from above, since GeoNet runs no availability service. NOA, National Observatory of Athens; AUTH, Aristotle University of Thessaloniki; HC is operated by the Technological Educational Institute of Crete.

any waveform is fetched, reach the target, 240 on KO and 150 on Greece and New Zealand, the crossing sequence included whole; a network that does not reach its target uses all of its sequences and is reported as under the target, as KO's two-month pool was expected to be.

Quiet windows. Each network also contributes up to 24 windows of 6 h, drawn at random over its test period with seed 43 on the station sets of its sequences, and accepted only if no cataloged event lies within 250 km of any of their stations during the window or 30 min on either side and their data cover 90% of it, small distant events being disregarded if 10 000 draws give fewer than 24. The first 30 min of each window are not scored.

3.2. Detectors

The pipeline's own detector, called the learned detector throughout, scores 6 s windows. Each window (600×3 samples at 100 Hz) is detrended, tapered, band-passed at 1–45 Hz, standardized per component and compressed with an inverse hyperbolic sine. The filter is zero-phase but applied within the window, whose last sample is the current time, so that no later sample is used; the standardization uses the window's own statistics, which removes gain and site amplitude. Three strided convolutional layers reduce the window to 75 steps of 96 channels, and a bidirectional LSTM with 48 units per direction, a four-head self-attention block with residual connection (Vaswani et al., 2017) and a small perceptron produce a single logit (142 059 parameters). The arrangement is that of CRED (Mousavi et al., 2019b) with the self-attention of EQTransformer's encoder (Mousavi et al., 2020), adapted from 1D2D-EDL (Wang and Zhao, 2025). The network was trained with label smoothing, three seeds are averaged, and the ensemble reaches a ROC-AUC of 0.9785 on the station-disjoint curated test set. A P/S picker, run only after a trigger, provides picks for location (Section S19).

The recursive STA/LTA band-passes the trace with fourth-order Butterworth sections, forms the squared vertical




Figure 2: Stations of the test networks: Greece (top left; HL, HT, HA, HP and HC by symbol), New Zealand (top right; the Tongariro and Ruapehu stations in a zoom inset, and the Chatham Islands station, east of 180°, in a second inset) and KO (bottom). Filled symbols are the stations usable in at least one of the four pre-test windows that set the per-station STA/LTA ratios, open symbols in their network's shape the stations probed there but not usable. The maps were drawn before the release date and show no event; the sequences selected afterwards are listed in Table 4. Relief from ETOPO 2022 (NOAA National Centers for Environmental Information, 2022).

component or the three-component energy, and agrees with SciPy (Virtanen et al., 2020) and ObsPy (Beyreuther et al., 2010; Krischer et al., 2015) to within rounding (Section S2). FilterPicker takes the maximum over a bank of band-pass characteristic functions and declares a pick when its mean over a window reaches a second threshold; the pipeline's

port of Lomax's C code gives identical picks (Section S12). EQTransformer and PhaseNet run through SeisBench 0.12.6 in place of the learned detector, each 6 s window receiving the largest model output within it, EQTransformer's detection trace or PhaseNet's P probability. In the *causal* mode the model input ends at the end of the window, as in real-time operation; in the *look-ahead* mode it is centered on it, an offline upper bound (Section S8). Each baseline replaces only the learned detector's output; triggers are limited to one per 15 s per station, and everything downstream is unchanged.

3.3. Real-time pipeline

The pipeline runs from ingestion to location and magnitude (Figure 3). Each station is served by an ingestion and a processing thread that feed one network stage through an ordered message bus, and the build is one binary and a directory of weights. Records are released when the replay clock reaches their last sample, which reproduces the arrival order of a live feed, and samples are held in a ring whose positions give their times, so that writes do not drop or wait (Section S2).

Windows are scored on an absolute grid every 0.5 s. Label smoothing makes the learned detector's outputs saturate between 0.90 and 0.907, so that a single threshold at $p \geq 0.9$ depends on the third decimal. The adopted rule, chosen on the tuning replays (Table S13), fires when eight consecutive windows reach $p \geq 0.8$, 3.5 s after the first, or when one window reaches $p \geq 0.9$; a trigger re-arms after two windows below 0.3, and no window within 15 s of the previous trigger may start a run. The P time of a learned trigger is the first sample in its window at which a recursive STA/LTA (2–20 Hz, 1 and 30 s, vertical) running alongside reaches a ratio of 3, otherwise 3.5 s into the window; this sample always lies in the past, and the anchoring adds no latency. Two detections are associated when their P times differ by no more than the P travel time between the stations plus 3 s, an event is declared when two stations agree, and later detections at a station within 40 s are absorbed as its coda. Location, a two-stage grid search in a half-space from accepted P and S picks, serves the report after the alarm and is not evaluated (Section S16).

All layers are implemented by hand and load the PyTorch (Paszke et al., 2019) parameters unchanged; agreement tests on real waveforms put the worst-case error of the detector logit at 6.0×10^{-7}, and repeated and concurrent replays produce byte-identical reports. On a Ryzen 5 5600 a window of the three-model ensemble costs 5.2 ms against 0.0005 ms for the STA/LTA, and one thread sustains 95 stations; on a Raspberry Pi 4 the static aarch64 build raises the same alarms at the same times and four cores sustain 52 stations (Table S4). The tests run the release's static x86-64 build, whose reports on all development replays equal the development build's.

3.4. Magnitude and early location

The magnitude is estimated from the peak displacement of the P wave, Pd (Wu and Kanamori, 2005; Kanamori, 2005), rather than learned. At each station with a gain, the raw vertical passes through a causal chain: a two-pole




Figure 3: Architecture of the real-time pipeline. Each station runs an ingestion and a processing thread; a network stage associates station detections, declares, locates and sizes events and scores them against a catalog. The recursive STA/LTA never triggers; it only supplies the reported P time of a learned trigger.

high-pass at 0.075 Hz, integration and the same high-pass. Pd(τ) is the largest absolute displacement in the τ s after the station's onset, for τ of 1, 2, 3, 4, 5, 7 and 10 s, with the noise level taken over the 10 s ending 1 s before it. The relation between $\log_{10}$Pd, magnitude and hypocentral distance has two magnitude slopes and three distance slopes per window and a term per station. An event's magnitude is the posterior mean of this relation's likelihood over its stations' values under a Gutenberg–Richter prior; a value below three times its noise level enters as an upper bound. The relation was fitted on 96 908 values from 11 806 KO events in a separate station-disjoint data set; on its test stations, from M3 upward, the estimate at $\tau = 5$ s has a bias within ± 0.05 and a mean absolute error of 0.12 to 0.21. With each estimate the pipeline reports the posterior probability of three size classes, below M4, M4 to 5.5, and above; for events larger than about M6.5 the estimate and its class are lower bounds. On KO the calibration's gains, station terms and noise levels apply, with its exclusion of channels whose noise lies far from their median. On Greece and New Zealand the gains come from each set's StationXML, and a vertical channel is accepted only if its response divided by the stated sensitivity lies within 0.8–1.25 between 0.1 and 5 Hz. On these two networks the station terms are set to zero and no noise levels apply, so that no channel is excluded for being dead or in a coda. KO's station terms average +0.07 to +0.10 in $\log_{10}$Pd, so zero terms bias an average station by about +0.1, against the relation's scatter of about 0.3.

Pd requires hypocentral distances before the picks of the 60 s picker window can locate an event. Each declared event is therefore also located from its detections' onsets alone, by a grid search in a uniform half-space at 10 km depth from three stations on, the onsets coming from a FilterPicker that runs beside the learned detector and triggers nothing (median onset error 0.06 s on 418 development arrivals). This location serves the Pd distances only, once its 68% radius is below 20 km, until a pick location replaces it (Section S16). None of this touches detection, association or matching: all development replays give the same alarms with and without it.

3.5. Scoring

Alarms without a catalog counterpart are called unmatched rather than false, because the catalogs are incomplete for small events during aftershock sequences; the false-alarm rate is measured on the quiet windows, as alarms per day with exact Poisson intervals. A declared event matches a catalog event if its epicenter lies within 30 km and its origin within 5 s, or if the predicted P arrival at a station that raised the alarm lies within 6 s of that station's P time, P being predicted in a uniform half-space. Each alarm is credited to the one catalog event it fits best, and each catalog event to the first alarm credited with it, so that no alarm counts for two events and a second alarm for the same event counts as unmatched. The chance level c is the detection rate with all catalog times shifted by ± 127, ± 263 and ± 391 s, as the time slides of gravitational-wave analysis measure accidental coincidences (Was et al., 2010), and with observed rate o the chance-corrected rate is

$$\hat{o} = (o - c)/(1 - c), \tag{2}$$

reported as an equivalent number of events; inside aftershock sequences most shifted events land within 60 s of a real one, so c overstates chance matching and the correction is conservative (Section S17). Window probabilities are cached, which reproduces full inference exactly. Two detectors are compared on per-event outcomes by an exact McNemar test and a paired bootstrap of the difference in chance-corrected detections (10 000 resamples within each sequence).

3.6. Test protocol

The protocol was committed to the pipeline's public repository and timestamped on Zenodo before any test waveform was fetched (release v1.0.0, commit 3e43064, 2026-10-30, doi:10.5281/zenodo.23806743), with the release that is tested, the hashes of each model file and of the static binary, and the code that fetches, replays and scores the data. It is summarized here and given in full in Section S24.

Detectors. The learned detector keeps the rule fixed on the tuning data. All baselines, STA/LTA, FilterPicker and the published PhaseNet and EQTransformer models, were retuned on 29 October 2026 on all development event replays, the four AFAD sequences and the KOERI M_{w} 4.9 window, 197 cataloged events, by three rules stated in advance. The first takes the most chance-corrected detections at no more unmatched alarms than the learned detector, the second the fewest unmatched alarms at no fewer chance-corrected detections, and the third the most chance-corrected detections at no more alarms than the learned detector on the AFAD quiet windows. Because some unmatched alarms in aftershock sequences are uncataloged earthquakes, more of them for a sensitive detector, the third rule matches the rate on data without cataloged seismicity instead. For the published models the third rule is applied within the weights the first

Table 3
Detector settings of the tests, selected on the development event replays.

Detector	Rule	Setting	Corr.	Unm.	Quiet
Learned	–	0.8 × 8, or 0.9 once	128.2	52	16
STA/LTA	1	1–10 Hz, 0.5/10 s, ratio 8, vertical	110.3	47	63
	2	1–10 Hz, 1/10 s, ratio 4, vertical	131.6	113	224
	3	1–10 Hz, 0.5/10 s, ratio 10, 3 components	64.8	27	12
STA/LTA, per station	–	rule 1, each station's own ratio (3–15)			
FilterPicker	1	6/10/0.4 s, thresholds 20 and 10	102.5	44	291
	2	6/10/0.4 s, thresholds 15 and 8	130.9	101	954
	3	6/10/0.4 s, thresholds 6 and 15	52.0	9	9
PhaseNet, causal	1	INSTANCE, 0.8 × 1	119.7	52	49
	2	INSTANCE, 0.5 × 4	128.3	70	29
	3	INSTANCE, 0.7 × 2	126.1	62	15
EQTransformer, causal	1	INSTANCE, 0.7 × 8	62.1	49	7
	2	INSTANCE, 0.3 × 8	128.5	183	26
	3	INSTANCE, 0.6 × 2	94.4	130	14
PhaseNet, look-ahead	1	INSTANCE, 0.7 × 4	123.2	52	12
	2	INSTANCE, 0.6 × 8	135.9	61	14
	3	INSTANCE, 0.7 × 1	138.1	74	16
EQTransformer, look-ahead	1	INSTANCE, 0.6 × 4	113.0	50	11
	2	original, 0.7 × 8	140.0	88	13
	3	original, 0.6 × 2	153.2	116	16

Note. Rules: 1, equal unmatched alarms; 2, equal chance-corrected detections; 3, equal quiet alarms. Corr. and Unm.: chance-corrected detections and unmatched alarms over the five development event replays (197 cataloged events); Quiet: alarms on the 23 AFAD quiet windows (102.8 h). STA/LTA: band, STA and LTA lengths, trigger ratio, components; it re-arms at a ratio of 1.5. FilterPicker: its three windows and two thresholds. Learned detector and published models: probability threshold × consecutive windows, with their weights (Michelini et al., 2021); the instant branch is off for the published models. The candidates were the original, STEAD, INSTANCE and ETHZ weights of EQTransformer and the STEAD, INSTANCE and ETHZ weights of PhaseNet. The look-ahead variants use input past the window and run offline only. The per-station STA/LTA has no development counts; its ratios come from each test network's own pre-test windows.

two select. A per-station STA/LTA stands for the per-station tuning of operational practice: the first rule's setting with each station's own trigger ratio, the lowest of eight values at which the station's trigger rate on four 6 h windows from before the test period does not exceed its network's median rate at ratio 8 (Section S24). Table 3 lists all settings. The pipeline's transformer detector is fixed in the same release and tested under the same protocol at its defaults; it is reported in a companion paper.

Endpoints. The primary endpoint, on each network, is (i) the difference in chance-corrected detections between the learned detector and STA/LTA at equal unmatched alarms over its sequences, with a 95% paired bootstrap interval resampled within each sequence. The secondary endpoints are (ii) the same difference against STA/LTA at equal quiet alarms and (iii) against each other detector; (iv) equivalence with causal PhaseNet by two one-sided tests at 5% with a margin of 10% of the scorable events; (v) each detector's alarm rate on the quiet windows, also without the network's two stations of most STA/LTA detections; (vi) the rule's adjacent settings (thresholds 0.75 and 0.85, 6 and

10 windows); (vii) the share of alarm detections declared before the predicted S, and the primary comparison on the events detected before S; (viii) on KO, the primary comparison on test-split stations apart from training-split ones; (ix) the magnitude's error, bias and class accuracy by band and the share of alarmed events with an estimate, for events no deeper than 40 km; and (x) alarm delay and warning time before S. Because the matcher predicts P and S in a uniform half-space, 3 to 12 s late for events deeper than 100 km, each detection endpoint is also reported for the events no deeper than 40 km. No multiplicity correction is applied, each secondary result is labeled as such, and nothing is retuned on test data. The stopping rule counts events from the catalog before any waveform is fetched; the endpoints use the events ayzek scores (those with a depth and a magnitude, with origin from 30 s after the replay's start to 30 s before its end), a few fewer per sequence.

Prospective tests. The same protocol is applied to New Zealand and KO data recorded after the release date, data that did not exist when the method was fixed: all qualifying sequences from that date on, until the target or 12 months, each fetched once when four weeks old, with 24 quiet windows drawn once the span has closed (Section S24). The archive delivers these data intact, so the test replays them and is not a live run.

4. Results

Section 4.1 summarizes what the development data showed before the release, which fixed the method and is not a test. Sections 4.2 to 4.6 report the protocol's endpoints on the three test networks, each separately. On a continuous 728-day record at one development station, the learned detector and the pipeline's STA/LTA have nearly equal event ROC-AUC (0.9892 and 0.9910) but the learned detector finds 1.6 times as many events at one window false alarm per day, and four offline detectors rank in the reverse order of event AUC at that budget (Section S14).

4.1. Development results

On the development data, at the settings in use before the retuning, the learned detector detected 36.4 of 66 events after correction for chance against 21.7 for STA/LTA at comparable unmatched alarms on the Sındırgı M_{w} 6.1 sequence (difference 14.7, 95% interval 5.9–23.7) and 35.1 of 56 against 29.1 on Simav, not significant; causal PhaseNet matched it on both. On the 102.8 h of quiet windows it raised 3.74 alarms per day against 75.4 for STA/LTA at equal unmatched alarms. Section S20 gives these results in full.

4.2. The selected test sets

The selections were run after the release date, on 30 and 31 October 2026, and each set was fetched and verified against its request record (Table 4). Greece reached its target with 11 sequences and 178 scorable events, New Zealand with 13 sequences and 154. KO's two-month pool held three qualifying sequences, two of them assigned to this study,

with 36 scorable events against a target of 240; as the protocol provides, both are used and the KO result is reported as under the target, an outcome the protocol anticipated. KO's quiet draws also fell short, 6 windows in 10 000 strict draws and 14 in 10 000 relaxed ones, against 24 for the other two networks. Two Greek stations, ZKR and KOKK, delivered no data in their window, so two Greek replays run on 5 and 7 stations. Four of New Zealand's 13 sequences start with an event deeper than 170 km.

Table 4
The test sets selected after the release date.

Network	Catalog events	Qualifying sequences	This study's / selected	Scorable events (target)	Stations per seq.	Quiet windows (draws)	Quiet hours
Greece	90 382	84	42 / 11	178 (150)	6–8	24 (2 059)	132
New Zealand	81 990	29	16 / 13	154 (150)	5–8	24 (551)	132
KO	5 693	3	2 / 2	36 (240), under	7, 6	14 (20 000, relaxed)	77

Note. Catalog events: all events of the network's catalog in the test period; KO's 36 are under its target. Qualifying: sequences by the rule of Section 3.1; this study's are those the draw assigned to it, selected those taken before the target was reached. Scorable events: the stopping rule's count. Quiet windows: accepted of the draws made; KO's first 10 000 draws accepted 6, the relaxed pass 14. Scored quiet hours: 5.5 h per window after the unscored lead-in. The sequences, their stations and the windows are listed in Section S21.

4.3. Detection: the primary endpoint

Table 5 gives each detector on each network. On Greece, the learned detector detected 150.3 chance-corrected events of 177 against 127.9 for STA/LTA at equal unmatched alarms: a difference of +22.4 (95% interval +11.7 to +33.5; exact McNemar $p = 0.0001$, 25 events detected by the learned detector only against 4 by STA/LTA only). The two settings did not, however, raise equal unmatched alarms on Greece, as they had on the development data: the learned detector raised 371 and STA/LTA 189, two thirds of the learned detector's in two sequences (121 at Epirus and 104 at Evia; Section 5). Restricted to the 175 events no deeper than 40 km the difference is the same, +22.4 (+11.3 to +33.6).

On New Zealand, the learned detector detected 84.2 chance-corrected events of 151 with 20 unmatched alarms, against 66.1 for STA/LTA at equal unmatched alarms, also with 20: a difference of +18.1 (95% interval +7.2 to +29.5; exact McNemar $p = 0.002$, 25 events detected by the learned detector only against 7 by STA/LTA only). Restricted to the 137 events no deeper than 40 km (14 deeper, none without a depth), the difference is +17.9 (+7.2 to +29.0).

On KO, under the target with 36 scorable events, the learned detector detected 15.5 chance-corrected events with 9 unmatched alarms against 13.0 for STA/LTA with 8: a difference of +2.5 (95% interval −0.5 to +5.9; $p = 0.25$, 3 events detected by the learned detector only and none by STA/LTA only). All 36 events are shallower than 40 km, so the restricted result is the same. Most of KO's events are below M2 in EMSC's catalog, where neither detector finds much, and both detected all four events of M4.5 and above.

Table 5
Each detector at its setting of Table 3 on the three test networks: chance-corrected detections (Corr.), unmatched alarms (Unm.), the difference from the learned detector with its 95% paired bootstrap interval, and alarms per day on the quiet windows.

	Greece (177)				New Zealand (151)				KO (36), under target			
Detector, rule	Corr.	Unm.	Difference	Quiet	Corr.	Unm.	Difference	Quiet	Corr.	Unm.	Difference	Quiet
learned	150.3	371	–	19.3	84.2	20	–	0.9	15.5	9	–	9.7
STA/LTA, 1	127.9	189	+22.4 (+11.7, +33.5)	20.7	66.1	20	+18.1 (+7.2, +29.5)	1.6	13.0	8	+2.5 (−0.5, +5.9)	20.9
STA/LTA, 2	138.9	401	+11.4 (+1.9, +21.0)	103.8	80.8	49	+3.4 (−7.2, +13.9)	6.0	16.6	56	−1.1 (−6.9, +4.6)	111.9
STA/LTA, 3	100.3	66	+50.0 (+36.7, +63.5)	3.3	40.7	7	+43.5 (+32.0, +55.1)	0.4	8.0	1	+7.5 (+3.0, +12.7)	3.4
STA/LTA, per station	130.4	160	+19.9 (+9.7, +30.5)	4.2	54.4	15	+29.8 (+17.8, +41.6)	2.2	10.0	4	+5.5 (+1.4, +9.9)	2.5
FilterPicker, 1	128.4	193	+21.9 (+11.0, +32.9)	44.9	89.2	67	−5.0 (−16.0, +5.6)	6.2	11.0	9	+4.5 (+0.6, +8.8)	31.2
FilterPicker, 2	133.7	581	+16.5 (+5.1, +28.1)	270.2	105.0	247	−20.9 (−32.6, −9.5)	28.0	13.7	56	+1.8 (−2.6, +6.4)	201.7
FilterPicker, 3	90.7	25	+59.6 (+46.9, +72.3)	2.4	58.1	7	+26.1 (+15.0, +37.2)	0.9	8.9	1	+6.7 (+2.3, +11.7)	1.6
PhaseNet causal, 1	145.3	229	+5.0 (−2.1, +12.9)	12.9	78.4	15	+5.8 (−3.4, +15.4)	0.4	10.0	3	+5.5 (+1.4, +9.9)	7.2
PhaseNet causal, 2	144.5	357	+5.8 (−2.3, +14.6)	25.4	98.7	43	−14.5 (−24.8, −4.7)	1.4	15.8	11	−0.3 (−3.3, +2.7)	11.5
PhaseNet causal, 3	143.9	271	+6.4 (−1.6, +14.6)	12.9	87.5	26	−3.3 (−12.5, +5.9)	0.4	11.9	6	+3.6 (+0.4, +7.7)	6.9
EQTransformer causal, 1	89.9	219	+60.4 (+45.7, +75.3)	3.6	25.9	13	+58.3 (+46.8, +70.0)	0.0	5.0	1	+10.5 (+5.2, +16.1)	1.6
EQTransformer causal, 2	137.3	687	+13.0 (+2.9, +23.5)	16.6	65.5	50	+18.6 (+7.8, +29.4)	1.3	10.8	10	+4.8 (−0.1, +9.9)	11.5
EQTransformer causal, 3	128.0	470	+22.2 (+10.6, +34.6)	8.6	44.4	27	+39.8 (+28.3, +51.1)	0.6	9.9	3	+5.7 (+0.6, +10.9)	4.4
Look-ahead, offline only												
PhaseNet, 1	143.9	266	+6.3 (−3.3, +16.0)	7.1	85.6	20	−1.5 (−11.9, +9.1)	0.2	11.0	3	+4.5 (+0.6, +8.8)	4.7
PhaseNet, 2	144.1	301	+6.2 (−2.9, +15.3)	8.2	88.7	25	−4.5 (−15.1, +6.3)	0.7	12.0	6	+3.5 (+0.3, +7.6)	6.9
PhaseNet, 3	145.6	352	+4.6 (−5.0, +14.6)	12.0	94.8	31	−10.6 (−21.3, −0.4)	0.7	12.0	7	+3.5 (−0.7, +7.9)	7.5
EQTransformer, 1	115.5	291	+34.8 (+22.7, +47.0)	7.1	30.5	9	+53.7 (+40.9, +66.3)	0.2	1.0	2	+14.5 (+8.6, +20.6)	3.4
EQTransformer, 2	150.6	291	−0.4 (−9.9, +9.0)	6.4	97.4	51	−13.3 (−24.8, −1.9)	2.5	17.8	3	−2.2 (−5.4, +0.0)	6.2
EQTransformer, 3	154.7	385	−4.4 (−13.5, +4.7)	9.3	104.0	73	−19.9 (−30.9, −8.9)	3.3	18.7	4	−3.2 (−6.7, −0.2)	9.0

Note. Rules as in Table 3; the per-station STA/LTA uses rule 1's setting with each station's own ratio. In parentheses after each network, the events ayzek scored. Unm.: unmatched alarms over the network's sequences. Quiet: alarms per day on the network's quiet windows (Table 4); the counts and the rate ratios with their exact intervals are in Table S22. The same table for the events no deeper than 40 km is Table S23. Rule 1 against the learned detector is the primary endpoint; all other rows are secondary.

4.4. Detection: secondary endpoints

All results of this section are secondary; Section S24 gives each in full, network by network.

The learned detector stayed ahead of the baselines whose settings kept their development operating point (Table 5): of STA/LTA at equal quiet alarms by +50.0 events on Greece and +43.5 on New Zealand, of the per-station STA/LTA by +19.9 and +29.8, and of causal EQTransformer by +60.4 and +58.3. FilterPicker at equal unmatched alarms was 21.9 events behind it on Greece and level on New Zealand, there at 67 unmatched alarms against 20. Causal PhaseNet was equivalent to the learned detector on Greece (+5.0; 90% interval −0.9 to +11.6, margin ±17.7) and New Zealand (+5.8; −1.8 to +13.9, ±15.1), with fewer unmatched alarms on both, and behind it on KO (+5.5, +1.9 to +9.5, ±3.6). The transformer was level on Greece and 17.5 events ahead on New Zealand, at 31 unmatched alarms against 20.

On the quiet windows the learned detector raised 0.9 alarms per day on New Zealand against 1.6 for STA/LTA at equal unmatched alarms (rate ratio 0.56, 0.15 to 1.85), 19.3 against 20.7 on Greece (0.93, 0.71 to 1.22) and 9.7 against 20.9 on KO (0.46, 0.29 to 0.72); on Greece and KO the settings matched on quiet alarms raised 1.6 to 4.2 per day. Leaving out each network's two stations with the most STA/LTA detections lowers the Greek rates to 12.2 and 5.8 and changes no other ordering. The rule's neighbors with 6 windows detected 11 to 20 more events than the rule on New Zealand and none more than 0.2 more on Greece; those with 10 windows detected fewer on both. At least 97% of the learned detector's alarm detections preceded the predicted S on each network, and restricted to the events

detected before S the primary difference is +15.7 on both unseen networks. KO's station-split comparison is empty, all its stations being training-split stations. Of the events of M4.5 and above, the learned detector missed one, a Greek MLh 4.9 that came 19 s after an M1.9 both detectors alarmed.

4.5. Magnitude

On Greece, under StationXML gains and zero station terms, all 10 alarmed events of M4 and above received an estimate. For the seven MLh 4 to 5.5 events no deeper than 40 km the final estimate has a bias of +0.09 and a mean absolute error of 0.11, with the size class right for all seven at the first and the final estimate; the MLh 5.8 of 29 March 2024 received M5.8 6.5 s after its alarm, and 56 of the 143 smaller alarmed events received an estimate, biased by +0.13. On New Zealand, under the same conditions, all 10 alarmed events of M4 and above received an estimate and 8 of the 77 smaller ones did. For the eight MLv 4 to 5.5 events no deeper than 40 km the final estimate has a bias of +0.03 and a mean absolute error of 0.20, with the size class right at the first and the final estimate for all eight; the expected bias of zero terms, about +0.1, is not visible at this count. On KO, with its calibration, the M_{w} 5.3 received M5.7 2.5 s after its alarm and M5.6 at the end, the mb 4.7 M4.7 then M4.8, the mb 4.6 M4.5 then M4.8, and the M5.0 no estimate. Deeper events are in Section S22.

4.6. Latency

On Greece the learned detector's alarms came a median 12.0 s after origin (10.0 to 13.5 s) and STA/LTA's 10.8 s (9.0 to 12.4 s), and 126 of 130 detected events had a station still ahead of S at the alarm, by a median 4.8 s at the nearest such station against 5.1 s for STA/LTA; the dense Greek networks place a station close to most sources. On New Zealand the learned detector's alarms came a median 16.0 s after origin (interquartile range 14.5 to 18.5 s) and STA/LTA's 14.2 s (13.5 to 17.0 s), the gap seen on the development data, and every detected event had a station still ahead of its S wave at the alarm, by a median 13.0 s for the learned detector and 14.7 s for STA/LTA. On KO the medians are 20.8 and 17.9 s, with 5.4 and 7.7 s of warning at the nearest station; the M_{w} 5.3 was declared 21.5 s after origin by the learned detector and 18.9 s by STA/LTA, 16 s before S at the nearest station.

5. Discussion

We argue that a detector for early warning should be evaluated at the operating point at which it will be used, on data it has not seen, and under a comparison fixed before those data were chosen, and this study was designed accordingly. On the development data the learned detector and the classical triggers separated clearly once matched on unmatched alarms and replayed on quiet data, whereas event-level ROC-AUC barely separates the pipeline's two detectors and ranks four offline ones in the reverse order of their recall (Section S14). The held-out tests answer the question posed in the Introduction. On New Zealand, a network no model had seen, the advantage held: 18 more chance-corrected

events than STA/LTA at equal unmatched alarms, out of 151, with an interval well clear of zero, and the same within 2 events for the shallow events alone and for the events detected before S. On Greece the difference was larger, 22 events out of 177, and the same for the shallow events, but it came with twice STA/LTA's unmatched alarms, so the comparison was not at an equal operating point there. On KO, held out in time from the network the detector was trained on, the difference had the same sign but with 36 events its interval includes zero, as the protocol anticipated for a two-month pool; the KO result is evidence of consistency, not a test of its own.

On these data the classical detectors are neither obsolete nor superior. On development data the learned detector gained in M2–4 events that an amplitude criterion cannot separate from noise, and it kept that sensitivity at a small fraction of the classical detectors' alarm rate on quiet data. On New Zealand it kept it: 0.9 alarms per day against 1.6 to 6.2 for the classical settings matched on detections or unmatched alarms. On Greece and KO it did not: 19.3 and 9.7 per day, while the baselines matched on quiet alarms stayed near their development rates. An analysis outside the protocol, made after the Greek result, separates two causes (Section S25). In the two Greek sequences with the most unmatched alarms, 77 of the learned detector's 225 locate within 30 km of the mainshock, most from P and S picks, and 9 more follow events listed by the Aristotle University network but absent from NOA's catalog, so at least 86 are uncataloged aftershocks; the other 141 could not be located. On the quiet windows, one 6 h window in Crete holds 51 of the learned detector's 106 Greek alarms, nearly all with station STIA, on emergent signals with no impulsive onset, no location and no event in any catalog; STA/LTA did not fire on them, so the protocol's exclusion of the two stations noisiest for STA/LTA did not remove them. Without that window the learned detector raised 10.4 alarms per day against 21.2. The learned detector is thus more sensitive both to small earthquakes missing from the catalogs and to a kind of emergent station noise that STA/LTA ignores, and an unmatched or quiet-window alarm count does not separate the two. The classical detectors alarm about a second earlier on the largest events, since a window detector can trigger only once the P wave occupies part of its 6 s window. They also cost orders of magnitude less and time the onset to a sample, which is what the pipeline uses them for. Causal PhaseNet, trained on another country's data, was equivalent to the learned detector on New Zealand under the equivalence test on both unseen networks, with fewer unmatched alarms, and behind it on KO. FilterPicker matched the learned detector's detections on New Zealand only at three times its unmatched alarms, and no published model that can run in real time exceeded the learned detector at an alarm rate matched on the development data. It does so in a self-contained program with 142 059 parameters per network.

Much of the protocol rests on the computational design: cached window probabilities and deterministic replays made trigger grids of hundreds of settings and the retuning of all baselines practical, and the release, the request records and the file hashes let anyone fetch the same test data again and check them. Only complete replays exposed two failures of the data path, among them an earlier version that dropped samples under load and lost 15 of 44 detections

(Section S2).

5.1. Limitations

The limitations below were stated in the protocol before any test waveform was fetched and are unchanged. The KO test is far under its target, with 36 events in two sequences and 14 quiet windows, so its interval is wide; the prospective KO test will add to it. The catalogs are incomplete for small events, so that unmatched alarms only bound false alarms, and EMSC's catalog lists fewer small events in KO's region than AFAD's does, which lowers KO's scorable counts and raises all detectors' unmatched alarms there. The matcher predicts P and S in a uniform half-space, so events deeper than about 150 km are scored as missed for all detectors alike, which the depth-restricted results address. On Greece and New Zealand the magnitude runs with zero station terms, an expected bias of about +0.1, and without the noise levels that exclude dead channels and codas on KO. Several parameters applied to all detectors were not swept: the 40 s coda absorption, which trades the resolution of closely spaced events for fewer false alarms, the 15 s between a station's triggers, the trigger's release, the pick checks and the location's velocities and depth. The learned detector responds to emergent station noise that STA/LTA ignores (Section 5), which the protocol's station exclusion, keyed to STA/LTA, does not catch. The ranking on a continuous record rests on one station, and the published models ran with pre-trained weights that fine-tuning might improve. The input is a replay of archived files; a live SeedLink client, with its latency, packet loss and clock problems, was not part of the tests.

6. Conclusions

A self-contained, verified real-time pipeline and a replay protocol with chance correction, paired tests and catalog-quiet data, fixed in a timestamped release before its test data were fetched, measure seismic detectors at their operating point. Under this protocol, on the Greek and New Zealand networks that no model had seen, a learned detector found 22.4 (Greece) and 18.1 (New Zealand) more chance-corrected events than STA/LTA at the settings matched on unmatched alarms, with 95% intervals 11.7–33.5 and 7.2–29.5, on Greece at twice STA/LTA's unmatched alarms; on the KO network it was trained on, held out in time and under its target, 2.5 more, with an interval including zero. On New Zealand's quiet data it raised a fraction of the classical detectors' alarms, on Greece's and KO's not, in part through station noise that STA/LTA ignores, and causal PhaseNet was equivalent to it on both unseen networks. Two detectors with nearly equal event AUC differed by a factor of 1.6 in recall at one window false alarm per day. Our results indicate that detectors for early warning are better compared on continuous records at fixed alarm budgets, under a comparison fixed before the records are seen.

CRediT authorship contribution statement

H. Oğuz Bolat: Conceptualization, Methodology, Software, Investigation, Formal analysis, Data curation, Visualization, Writing – original draft. **Sibel Çimen:** Writing – review and editing. **Bülent Bolat:** Writing – review and editing, Supervision. **Tülay Yıldırım:** Writing – review and editing, Supervision.

Code availability

Name of the software: ayzek. Developer: H. Oğuz Bolat (oguz.bolat@std.yildiz.edu.tr), first available in September 2026. Program language: C++23, with Python tools for model export and evaluation. Hardware requirements: an x86-64 or aarch64 processor; tested on a desktop computer and on a Raspberry Pi 4. Software required: Meson and Ninja and a C++23 compiler (GCC 16 or Clang); no machine-learning runtime. Program size: about 9 400 lines of C++ and 6.5 MB of model weights. License: GNU General Public License, version 3 or later. The source code, model weights, the protocol, the test settings, the documentation and the scripts that reproduce each result (`tools/reproduce_all.sh`, with expected values in `bench/claims.json`; `tools/run_heldout.py` for the tests) are available at `https://github.com/hogib/ayzek`. The tests run release v1.0.0 (commit 3e43064, 30 October 2026), archived at `https://doi.org/10.5281/zenodo.23806743`; the release carries the SHA-256 of its static x86-64 binary and of each model file, and the tool that fetches the test data at commit 440a2d9, as a tarball; the tool's repository is `https://github.com/hogib/ayzek-heldout`. The FilterPicker port is derived from the C code of Lomax et al. (2012) (GNU GPL version 2 or later). Software versions are listed in Table S9.

Data availability

The AFAD waveforms are available from AFAD's data portal (TDVMS, `https://tdvms.afad.gov.tr`) on registration and request, and cannot be redistributed. The KOERI (Kandilli Observatory and Earthquake Research Institute (KOERI), Boğaziçi University, 1971), Greek (National Observatory of Athens, Institute of Geodynamics, Athens, 1975; Aristotle University of Thessaloniki, 1981; University of Athens, 2008; University of Patras, 2000; Technological Educational Institute of Crete, 2006) and New Zealand (GNS Science, 2021) waveforms are open, KOERI's under citation of the network, the Greek networks' under CC BY 4.0 from the NOA EIDA node, and GeoNet's under CC BY 3.0 NZ. The test waveforms are not redistributed: they are fetched from these data centers by the tool released with the pipeline, which keeps for each set a record of the request (`dataset.json`: services, stations, channels and windows, the canary check, and what arrived) and the SHA-256 of each file it wrote, so that a later fetch can be checked against the data used in this study. The selection of the sequences and quiet windows, the station tables and the catalog requests are released with it. After the release the fetch tool received three commits (658ae03, 5d088c5 and 6fda3e2) that change only how it retries and splits its requests to NOA's availability service, none of what it selects

or writes; KO was selected and fetched at 440a2d9, New Zealand and Greece fetched at 6fda3e2, as each set's record states. The catalogs are AFAD's for the development replays, EMSC's (European-Mediterranean Seismological Centre (EMSC), 2026) for the KO tests, which the European-Mediterranean Seismological Centre serves through its FDSN event service with the Turkish agencies' solutions (KOERI runs no event service, and AFAD's answered each request made when the protocol was written with an empty list), NOA's FDSN event service for Greece and GeoNet's (GNS Science, 1970) for New Zealand. The three public KOERI development sets are attached to the pipeline's release. The offline evaluation code is available at `https://github.com/SismoKaos-Research/cnn_earthquake`, the training code of the detector at `https://github.com/hogib/cascade` and that of the picker at `https://github.com/hogib/sphase`. Maps use ETOPO 2022 (NOAA National Centers for Environmental Information, 2022), GSHHG (Wessel and Smith, 1996) and GMT (Wessel et al., 2019).

Declaration of competing interests

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Funding

This research did not receive any specific grant from funding agencies in the public, commercial, or not-for-profit sectors.

Acknowledgments

The authors thank AFAD and KOERI for access to their waveform data and earthquake catalogs. We acknowledge the New Zealand GeoNet programme and its sponsors NHC, Earth Sciences NZ, LINZ, NEMA and MBIE. The Greek waveforms were retrieved from the EIDA node of the National Observatory of Athens, and we thank the operators of the HL, HT, HA, HP and HC networks: the National Observatory of Athens, the Aristotle University of Thessaloniki, the University of Athens, the University of Patras and the Technological Educational Institute of Crete. The KO test catalog was retrieved from the FDSN event service of the European-Mediterranean Seismological Centre.

Declaration of generative AI and AI-assisted technologies in the manuscript preparation process

During the preparation of this work the authors used Claude Opus 5, Claude Opus 5.5 and Claude Fable 5.1 (Anthropic) to develop and refactor parts of the pipeline code and to edit the manuscript text. After using these tools,

the authors reviewed and edited the content as needed and take full responsibility for the content of the published article.

References

Alcik, H., Ozel, O., Apaydin, N., Erdik, M., 2009. A study on warning algorithms for Istanbul earthquake early warning system. Geophysical Research Letters 36, L00B05. doi:10.1029/2008GL036659.

Allen, R.M., Gasparini, P., Kamigaichi, O., Böse, M., 2009. The status of earthquake early warning around the world: An introductory overview. Seismological Research Letters 80, 682–693. doi:10.1785/gssrl.80.5.682.

Allen, R.V., 1978. Automatic earthquake recognition and timing from single traces. Bulletin of the Seismological Society of America 68, 1521–1532. doi:10.1785/BSSA0680051521.

Aristotle University of Thessaloniki, 1981. Hellenic Unified Seismological Network. International Federation of Digital Seismograph Networks, data set. doi:10.7914/SN/HT.

Behr, Y., Clinton, J.F., Cauzzi, C., Hauksson, E., Jónsdóttir, K., Marius, C.G., Pinar, A., Salichon, J., Sokos, E., 2016. The virtual seismologist in seiscomp3: A new implementation strategy for earthquake early warning algorithms. Seismological Research Letters 87, 363–373. doi:10.1785/0220150235.

Beyreuther, M., Barsch, R., Krischer, L., Megies, T., Behr, Y., Wassermann, J., 2010. ObsPy: A Python toolbox for seismology. Seismological Research Letters 81, 530–533. doi:10.1785/gssrl.81.3.530.

Bracale, M., Colombelli, S., Elia, L., Karakostas, V., Zollo, A., 2021. Design, implementation and testing of a network-based earthquake early warning system in greece. Frontiers in Earth Science 9, 667160. doi:10.3389/feart.2021.667160.

Brooks, B.A., Protti, M., Ericksen, T., Bunn, J., Vega, F., Cochran, E.S., Duncan, C., Avery, J., Minson, S.E., Chaves, E., Baez, J.C., Foster, J., Glennie, C.L., 2021. Robust earthquake early warning at a fraction of the cost: Astuti costa rica. AGU Advances 2, e2021AV000407. doi:10.1029/2021av000407.

Budakolu, E., Tunç, S., Tunç, B., Çaka, D., 2026. Magnitude scaling and real-time performance assessment for an elarms-based early warning system: The case of the 2025 silivri (istanbul) earthquake (mw = 6.2). Applied Sciences 16, 677. doi:10.3390/app16020677.

Chakraborty, M., Fenner, D., Li, W., Faber, J., Zhou, K., Rümpker, G., Stoecker, H., Srivastava, N., 2022. Creime—a convolutional recurrent model for earthquake identification and magnitude estimation. Journal of Geophysical Research: Solid Earth 127, e2022JB024595. doi:10.1029/2022jb024595.

Chung, A.I., Henson, I., Allen, R.M., 2019. Optimizing earthquake early warning performance: ElarmS-3. Seismological Research Letters 90, 727–743. doi:10.1785/0220180192.

Cochran, E.S., Kohler, M.D., Given, D.D., Guiwits, S., Andrews, J., Meier, M.A., Ahmad, M., Henson, I., Hartog, R., Smith, D., 2018. Earthquake early warning ShakeAlert system: Testing and certification platform. Seismological Research Letters 89, 108–117. doi:10.1785/0220170138.

Davis, J., Goadrich, M., 2006. The relationship between precision-recall and ROC curves, in: Proceedings of the 23rd International Conference on Machine Learning, pp. 233–240. doi:10.1145/1143844.1143874.

Disaster and Emergency Management Authority (AFAD), 1990. Turkish National Seismic Network. International Federation of Digital Seismograph Networks, data set. doi:10.7914/SN/TU.

European-Mediterranean Seismological Centre (EMSC), 2026. EMSC earthquake catalogue. FDSN event service, https://www.seismicportal.eu/fdsnws/event/1/. No DOI; accessed 2026-10-30 (the KO selection) and 2026-10-30 to 2026-10-31 (the KO sets' catalog excerpts).

Fawcett, T., 2006. An introduction to ROC analysis. Pattern Recognition Letters 27, 861–874. doi:10.1016/j.patrec.2005.10.010.

GNS Science, 1970. GeoNet Aotearoa New Zealand Earthquake Catalogue. data set, accessed 2026-10-30 to 2026-10-31. doi:10.21420/0S8P-TZ38.

GNS Science, 2021. GeoNet Aotearoa New Zealand Seismic Digital Waveform Dataset. data set. doi:10.21420/G19Y-9D40.

Hoshiba, M., Kamigaichi, O., Saito, M., Tsukada, S., Hamada, N., 2008. Earthquake early warning starts nationwide in japan. Eos, Transactions American Geophysical Union 89, 73–74. doi:10.1029/2008eo080001.

Hsiao, N.C., Wu, Y.M., Shin, T.C., Zhao, L., Teng, T.L., 2009. Development of earthquake early warning system in taiwan. Geophysical Research Letters 36, L00B02. doi:10.1029/2008gl036596.

Kanamori, H., 2005. Real-time seismology and earthquake damage mitigation. Annual Review of Earth and Planetary Sciences 33, 195–214. doi:10.1146/annurev.earth.33.092203.122626.

Kandilli Observatory and Earthquake Research Institute (KOERI), Boğaziçi University, 1971. Kandilli Observatory and Earthquake Research Institute (KOERI) seismic network. International Federation of Digital Seismograph Networks, data set. doi:10.7914/SN/KO.

Kandilli Observatory and Earthquake Research Institute (KOERI), Boğaziçi University, 2013a. Istanbul University Seismic Network. International Federation of Digital Seismograph Networks, data set. doi:10.7914/SN/IJ.

Kandilli Observatory and Earthquake Research Institute (KOERI), Boğaziçi University, 2013b. MARsite Project. International Federation of Digital Seismograph Networks, data set. doi:10.7914/SN/6G_2013.

Kodera, Y., Hayashimoto, N., Moriwaki, K., Noguchi, K., Saito, J., Akutagawa, J., Adachi, S., Morimoto, M., Okamoto, K., Honda, S., Hoshiba, M., 2020. First-year performance of a nationwide earthquake early warning system using a wavefield-based ground-motion prediction algorithm in japan. Seismological Research Letters 91, 826–834. doi:10.1785/0220190263.

Kohler, M.D., Cochran, E.S., Given, D., Guiwits, S., Neuhauser, D., Henson, I., Hartog, R., Bodin, P., Kress, V., Thompson, S., Felizardo, C., Brody, J., Bhadha, R., Schwarz, S., 2018. Earthquake early warning ShakeAlert system: West Coast wide production prototype. Seismological Research Letters 89, 99–107. doi:10.1785/0220170140.

Kohler, M.D., Smith, D.E., Andrews, J., Chung, A.I., Hartog, R., Henson, I., Given, D.D., de Groot, R., Guiwits, S., 2020. Earthquake early warning ShakeAlert 2.0: public rollout. Seismological Research Letters 91, 1763–1775. doi:10.1785/0220190245.

Krischer, L., Megies, T., Barsch, R., Beyreuther, M., Lecocq, T., Caudron, C., Wassermann, J., 2015. ObsPy: A bridge for seismology into the scientific Python ecosystem. Computational Science & Discovery 8, 014003. doi:10.1088/1749-4699/8/1/014003.

Lomax, A., Satriano, C., Vassallo, M., 2012. Automatic picker developments and optimization: FilterPicker—a robust, broadband picker for real-time seismic monitoring and earthquake early warning. Seismological Research Letters 83, 531–540. doi:10.1785/gssrl.83.3.531.

Marcou, S., Lux, A.I., Akimov, A., Williamson, A.L., Allen, R.M., 2025. Exploring end-to-end earthquake early warning performance in large earthquakes using the february 2023 kahramanmara, türkiye sequence. Scientific Reports 16, 327. doi:10.1038/s41598-025-29755-z.

Massin, F., Clinton, J., Böse, M., 2021. Status of earthquake early warning in switzerland. Frontiers in Earth Science 9, 707654. doi:10.3389/feart.2021.707654.

McClish, D.K., 1989. Analyzing a portion of the ROC curve. Medical Decision Making 9, 190–195. doi:10.1177/0272989X8900900307.

Meier, M.A., Kodera, Y., Böse, M., Chung, A., Hoshiba, M., Cochran, E., Minson, S., Hauksson, E., Heaton, T., 2020. How often can earthquake early warning systems alert sites with high-intensity ground motion? Journal of Geophysical Research: Solid Earth 125, e2019JB017718. doi:10.1029/2019jb017718.

Michelini, A., Cianetti, S., Gaviano, S., Giunchi, C., Jozinović, D., Lauciani, V., 2021. INSTANCE—the Italian seismic dataset for machine learning. Earth System Science Data 13, 5509–5544. doi:10.5194/essd-13-5509-2021.

Mousavi, S.M., Ellsworth, W.L., Zhu, W., Chuang, L.Y., Beroza, G.C., 2020. Earthquake transformer—an attentive deep-learning model for simultaneous earthquake detection and phase picking. Nature Communications 11, 3952. doi:10.1038/s41467-020-17591-w.

548 Mousavi, S.M., Sheng, Y., Zhu, W., Beroza, G.C., 2019a. STanford EArthquake Dataset (STEAD): A global data set of seismic signals for AI.
549 IEEE Access 7, 179464–179476. doi:10.1109/ACCESS.2019.2947848.
550 Mousavi, S.M., Zhu, W., Sheng, Y., Beroza, G.C., 2019b. CRED: A deep residual network of convolutional and recurrent units for earthquake
551 signal detection. Scientific Reports 9, 10267. doi:10.1038/s41598-019-45748-1.
552 Münchmeyer, J., Woollam, J., Rietbrock, A., Tilmann, F., Lange, D., Bornstein, T., Diehl, T., Giunchi, C., Haslinger, F., Jozinović, D., Michelini,
553 A., Saul, J., Soto, H., 2022. Which picker fits my data? A quantitative evaluation of deep learning based seismic pickers. Journal of Geophysical
554 Research: Solid Earth 127, e2021JB023499. doi:10.1029/2021JB023499.
555 National Observatory of Athens, Institute of Geodynamics, Athens, 1975. Hellenic Unified Seismological Network. International Federation of
556 Digital Seismograph Networks, data set. doi:10.7914/SN/HL.
557 NOAA National Centers for Environmental Information, 2022. ETOPO 2022 15 Arc-Second Global Relief Model. data set. doi:10.25921/fd45-gt74.
558 Nof, R.N., Kurzon, I., 2021. Truaa—earthquake early warning system for israel: Implementation and current status. Seismological Research Letters
559 92, 325–341. doi:10.1785/0220200176.
560 Paszke, A., Gross, S., Massa, F., Lerer, A., Bradbury, J., Chanan, G., Killeen, T., Lin, Z., Gimelshein, N., Antiga, L., Desmaison, A., Köpf, A.,
561 Yang, E., DeVito, Z., Raison, M., Tejani, A., Chilamkurthy, S., Steiner, B., Fang, L., Bai, J., Chintala, S., 2019. PyTorch: An imperative style,
562 high-performance deep learning library, in: Advances in Neural Information Processing Systems 32, pp. 8024–8035.
563 Perol, T., Gharbi, M., Denolle, M., 2018. Convolutional neural network for earthquake detection and location. Science Advances 4, e1700578.
564 doi:10.1126/sciadv.1700578.
565 Porras, J., Massin, F., Arroyo-Solórzano, M., Arroyo, I., Linkimer, L., Böse, M., Clinton, J., 2021. Preliminary results of an earthquake early
566 warning system in costa rica. Frontiers in Earth Science 9, 700843. doi:10.3389/feart.2021.700843.
567 Prasanna, R., Chandrakumar, C., Nandana, R., Holden, C., Punchihewa, A., Becker, J.S., Jeong, S., Liyanage, N., Ravishan, D., Sampath, R., Tan,
568 M.L., 2022. “saving precious seconds”—a novel approach to implementing a low-cost earthquake early warning system with node-level detection
569 and alert generation. Informatics 9, 25. doi:10.3390/informatics9010025.
570 Ross, Z.E., Meier, M.A., Hauksson, E., Heaton, T.H., 2018. Generalized seismic phase detection with deep learning. Bulletin of the Seismological
571 Society of America 108, 2894–2901. doi:10.1785/0120180080.
572 Saito, T., Rehmsmeier, M., 2015. The precision-recall plot is more informative than the ROC plot when evaluating binary classifiers on imbalanced
573 datasets. PLoS ONE 10, e0118432. doi:10.1371/journal.pone.0118432.
574 Suárez, G., 2022. The seismic early warning system of mexico (sasmex): A retrospective view and future challenges. Frontiers in Earth Science
575 10, 827236. doi:10.3389/feart.2022.827236.
576 Technological Educational Institute of Crete, 2006. Seismological Network of Crete. International Federation of Digital Seismograph Networks,
577 data set. doi:10.7914/SN/HC.
578 Tunç, S., Budakolu, E., Tunç, B., Çaka, D., 2024. Development of earthquake early warning algorithm magnitude scale for the 2023 kahramanmara
579 earthquake region. Engineering Science and Technology, an International Journal 57, 101815. doi:10.1016/j.jestch.2024.101815.
580 University of Athens, 2008. Hellenic Unified Seismological Network, University of Athens, Seismological Laboratory. International Federation of
581 Digital Seismograph Networks, data set. doi:10.7914/SN/HA.
582 University of Patras, 2000. Hellenic Unified Seismological Network. International Federation of Digital Seismograph Networks, data set. doi:10.
583 7914/SN/HP.
584 Vaswani, A., Shazeer, N., Parmar, N., Uszkoreit, J., Jones, L., Gomez, A.N., Kaiser, Ł., Polosukhin, I., 2017. Attention is all you need, in: Advances
585 in Neural Information Processing Systems 30, pp. 5998–6008.

Virtanen, P., Gommers, R., Oliphant, T.E., Haberland, M., Reddy, T., Cournapeau, D., Burovski, E., Peterson, P., Weckesser, W., Bright, J., van der Walt, S.J., Brett, M., Wilson, J., Millman, K.J., Mayorov, N., Nelson, A.R.J., Jones, E., Kern, R., Larson, E., Carey, C.J., Polat, İ., Feng, Y., Moore, E.W., VanderPlas, J., Laxalde, D., Perktold, J., Cimrman, R., Henriksen, I., Quintero, E.A., Harris, C.R., Archibald, A.M., Ribeiro, A.H., Pedregosa, F., van Mulbregt, P., SciPy 1.0 Contributors, 2020. SciPy 1.0: Fundamental algorithms for scientific computing in Python. Nature Methods 17, 261–272. doi:10.1038/s41592-019-0686-2.

Wang, L., Zhao, W., 2025. An ensemble deep learning network based on 2D convolutional neural network and 1D LSTM with self-attention for bearing fault diagnosis. Applied Soft Computing 172, 112889. doi:10.1016/j.asoc.2025.112889.

Was, M., Bizouard, M.A., Brisson, V., Cavalier, F., Davier, M., Hello, P., Leroy, N., Robinet, F., Vavoulidis, M., 2010. On the background estimation by time slides in a network of gravitational wave detectors. Classical and Quantum Gravity 27, 015005. doi:10.1088/0264-9381/27/1/015005.

Wessel, P., Luis, J.F., Uieda, L., Scharroo, R., Wobbe, F., Smith, W.H.F., Tian, D., 2019. The Generic Mapping Tools version 6. Geochemistry, Geophysics, Geosystems 20, 5556–5564. doi:10.1029/2019GC008515.

Wessel, P., Smith, W.H.F., 1996. A global, self-consistent, hierarchical, high-resolution shoreline database. Journal of Geophysical Research: Solid Earth 101, 8741–8743. doi:10.1029/96JB00104.

Withers, M., Aster, R., Young, C., Beiriger, J., Harris, M., Moore, S., Trujillo, J., 1998. A comparison of select trigger algorithms for automated global seismic phase and event detection. Bulletin of the Seismological Society of America 88, 95–106. doi:10.1785/BSSA0880010095.

Woollam, J., Münchmeyer, J., Tilmann, F., Rietbrock, A., Lange, D., Bornstein, T., Diehl, T., Giunchi, C., Haslinger, F., Jozinović, D., Michelini, A., Saul, J., Soto, H., 2022. SeisBench—a toolbox for machine learning in seismology. Seismological Research Letters 93, 1695–1709. doi:10.1785/0220210324.

Wu, Y.M., Chen, D.Y., Lin, T.L., Hsieh, C.Y., Chin, T.L., Chang, W.Y., Li, W.S., Ker, S.H., 2013. A high-density seismic network for earthquake early warning in taiwan based on low cost sensors. Seismological Research Letters 84, 1048–1054. doi:10.1785/0220130085.

Wu, Y.M., Kanamori, H., 2005. Rapid assessment of damage potential of earthquakes in Taiwan from the beginning of P waves. Bulletin of the Seismological Society of America 95, 1181–1185. doi:10.1785/0120040193.

Yeck, W.L., Patton, J.M., Ross, Z.E., Hayes, G.P., Guy, M.R., Ambruz, N.B., Shelly, D.R., Benz, H.M., Earle, P.S., 2021. Leveraging deep learning in global 24/7 real-time earthquake monitoring at the National Earthquake Information Center. Seismological Research Letters 92, 469–480. doi:10.1785/0220200178.

Zhu, W., Beroza, G.C., 2019. PhaseNet: A deep-neural-network-based seismic arrival-time picking method. Geophysical Journal International 216, 261–273. doi:10.1093/gji/ggy423.

Zhu, W., Hou, A.B., Yang, R., Datta, A., Mousavi, S.M., Ellsworth, W.L., Beroza, G.C., 2023. Quakeflow: a scalable machine-learning-based earthquake monitoring workflow with cloud computing. Geophysical Journal International 232, 684–693. doi:10.1093/gji/ggac355.

Zollo, A., Iannaccone, G., Lancieri, M., Cantore, L., Convertito, V., Emolo, A., Festa, G., Gallovi, F., Vassallo, M., Martino, C., Satriano, C., Gasparini, P., 2009. Earthquake early warning system in southern italy: Methodologies and performance evaluation. Geophysical Research Letters 36, L00B07. doi:10.1029/2008gl036689.