

Request fits the modeled conditions

The proposed 5.0 MW increment fits within the fixture’s modeled 5.8 MW increment. The unchanged workload still requires operational and commercial review.

DEMO-01 · Fictional facility electrical meter

All MW figures are additional load above a steady 20.0 MW reference. Authored UTC window: 2026-09-22T00:00:00Z to 2026-09-22T01:00:00Z.

Synthetic teaching scenario. No customer result or equipment-control authority.

One scope, one hour, distinct quantities

Nominal increment	12.0 MW
Modeled eligible increment	5.8 MW
Requested workload	5.0 MW
Proposed revised workload	No revision proposed
Operator-accepted / observed delivered	Not applicable / Not applicable

Requested profile: demo-01-a-requested.
Revised profile: Not applicable.

Governing conditions

Request within the modeled increment: 5.0 MW is below 5.8 MW for this fictional meter and hour. This is a model screening result only.

Boundary, hour, operating reserve, cooling evidence, and workload requirements must be reviewed together.

Business decision still to resolve

Do the workload’s service requirements and the site’s operating conditions support this commitment?

Economics unestimated. No price, utilization, investment cost, or commercial service requirement has been assessed.

What this does not establish

Physical feasibility, commercial usefulness, customer report acceptance, operational capacity acceptance, and equipment authority require separate evidence and decisions.

Phasing, another time window, cooling investment, and bridge power are unassessed investigation options, not evaluated alternatives.