

0016GBO, moulin à grains, janvier
21 journées, plaque 7 500 W, 9 critères tenus sur 10

NRMSE 11,2 % ≤ 15,4	LDC 5,2 % ≤ 11,8	FFT 7,6 % ≤ 20,0	Énergie −0,3 % ≤ 20,0	Pointe −20,5 % > 20,0
Fact. de charge 3,7 % ≤ 10,0	CORR_h 2,1 % ≤ 10,0	TVD_h 8,0 % ≤ 19,2	EXT_prof 16,0 % ≤ 43,6	Heure des pics 1,2 h ≤ 2,0
Forme 1 h 3,1 σ ≤ 3,4	Forme 2 h 3,0 σ ≤ 3,6	Pire écart 1 h 11,8 % ≤ 38,8	Verdict rejetée	Pointe jour. P95 1 508 / 1 854 W

