

0043SAM, moulin à grains, decembre
10 journées, plaque 7 500 W, 9 critères tenus sur 10

NRMSE 6,9 % ≤ 20,0	LDC 3,9 % ≤ 20,0	FFT 14,4 % ≤ 20,0	Énergie +1,0 % ≤ 20,0	Pointe −7,4 % ≤ 20,0
Fact. de charge 1,8 % ≤ 11,0	CORR_h 0,9 % ≤ 10,0	TVD_h 5,4 % ≤ 20,0	EXT_prof 9,3 % ≤ 50,0	Heure des pics 2,2 h > 2,0
Forme 1 h 2,4 σ ≤ 3,3	Forme 2 h 1,0 σ ≤ 3,4	Pire écart 1 h 12,3 % ≤ 64,1	Verdict non vérifiable	Pointe jour. P95 5 502 / 5 807 W

