

0043SAM, moulin à grains, janvier

30 journées, plaque 7 500 W, 9 critères tenus sur 10

NRMSE 9,5 % ≤ 20,0	LDC 5,5 % ≤ 20,0	FFT 12,8 % ≤ 20,0	Énergie −4,7 % ≤ 20,0	Pointe −11,3 % ≤ 20,0
Fact. de charge 2,0 % ≤ 13,5	CORR_h 1,2 % ≤ 10,0	TVD_h 5,1 % ≤ 20,0	EXT_prof 11,1 % ≤ 50,0	Heure des pics 3,0 h > 2,0
Forme 1 h 1,4 σ ≤ 3,2	Forme 2 h 1,1 σ ≤ 3,3	Pire écart 1 h 14,8 % ≤ 71,5	Verdict non vérifiable	Pointe jour. P95 5 002 / 5 550 W

