



0043SAM, moulin à grains, mars

51 journées, plaque 7 500 W, 9 critères tenus sur 10

NRMSE 5,9 % $\leq$ 20,0	LDC 4,0 % $\leq$ 20,0	FFT 13,6 % $\leq$ 20,0	Énergie +0,6 % $\leq$ 20,0	Pointe −7,5 % $\leq$ 20,0
Fact. de charge 2,8 % $\leq$ 10,0	CORR_h 1,2 % $\leq$ 5,0	TVD_h 5,0 % $\leq$ 10,0	EXT_prof 11,6 % $\leq$ 50,0	Heure des pics 3,0 h $>$ 1,8
Forme 1 h 1,3 $\sigma \leq$ 2,6	Forme 2 h 0,8 $\sigma \leq$ 2,5	Pire écart 1 h 11,2 % $\leq$ 51,6	Verdict non vérifiable	Pointe jour. P95 6 000 / 7 385 W



Courbe classée, LDC 4,0 %



Harmoniques, FFT 13,6 %

