

0097SAM, moulin à grains, avril
54 journées, plaque 7 350 W, 9 critères tenus sur 10

NRMSE 7,4 % $\leq$ 10,0	LDC 4,8 % $\leq$ 10,0	FFT 12,6 % $\leq$ 20,0	Énergie −0,8 % $\leq$ 11,6	Pointe −16,0 % $\leq$ 20,0
Fact. de charge 4,0 % $\leq$ 10,0	CORR_h 1,3 % $\leq$ 5,0	TVD_h 5,8 % $\leq$ 10,9	EXT_prof 9,4 % $\leq$ 25,0	Heure des pics 3,0 h $>$ 2,0
Forme 1 h 2,1 $\sigma \leq$ 3,3	Forme 2 h 1,7 $\sigma \leq$ 3,2	Pire écart 1 h 13,9 % $\leq$ 23,2	Verdict rejetée	Pointe jour. P95 4 905 / 6 844 W

