

# 0097SAM, moulin à grains, mai

## 40 journées, plaque 7 350 W, 8 critères tenus sur 10

|                                             |                                           |                                             |                                       |                                            |
|---------------------------------------------|-------------------------------------------|---------------------------------------------|---------------------------------------|--------------------------------------------|
| <b>NRMSE</b><br>6,8 % $\leq$ 10,0           | <b>LDC</b><br>4,4 % $\leq$ 10,0           | <b>FFT</b><br>20,7 % $>$ 20,0               | <b>Énergie</b><br>−0,5 % $\leq$ 15,2  | <b>Pointe</b><br>−8,1 % $\leq$ 20,0        |
| <b>Fact. de charge</b><br>1,6 % $\leq$ 10,0 | <b>CORR_h</b><br>1,8 % $\leq$ 5,0         | <b>TVD_h</b><br>7,2 % $\leq$ 10,1           | <b>EXT_prof</b><br>13,7 % $\leq$ 25,0 | <b>Heure des pics</b><br>1,5 h $>$ 1,0     |
| <b>Forme 1 h</b><br>3,2 $\sigma \leq$ 3,3   | <b>Forme 2 h</b><br>1,9 $\sigma \leq$ 3,3 | <b>Pire écart 1 h</b><br>12,3 % $\leq$ 22,1 | <b>Verdict</b><br>rejetée             | <b>Pointe jour. P95</b><br>6 860 / 7 042 W |

