

0097SAM, moulin à grains, mars
54 journées, plaque 7 350 W, 8 critères tenus sur 10

NRMSE 6,1 % ≤ 12,1	LDC 2,5 % ≤ 10,0	FFT 26,7 % > 20,0	Énergie −0,0 % ≤ 10,0	Pointe +0,0 % ≤ 20,0
Fact. de charge −0,0 % ≤ 10,0	CORR_h 1,0 % ≤ 5,0	TVD_h 5,2 % ≤ 11,3	EXT_prof 8,3 % ≤ 25,0	Heure des pics 3,0 h > 2,0
Forme 1 h 2,5 σ ≤ 3,1	Forme 2 h 1,5 σ ≤ 3,1	Pire écart 1 h 12,3 % ≤ 32,1	Verdict rejetée	Pointe jour. P95 5 394 / 6 380 W

