

0097SAM, moulin à grains, novembre

24 journées, plaque 7 350 W, 8 critères tenus sur 10

NRMSE 9,0 % ≤ 14,3	LDC 4,8 % ≤ 10,0	FFT 22,0 % > 20,0	Énergie −3,0 % ≤ 10,0	Pointe −16,1 % ≤ 20,0
Fact. de charge 3,1 % ≤ 10,0	CORR_h 2,3 % ≤ 8,5	TVD_h 9,8 % ≤ 16,6	EXT_prof 12,5 % ≤ 36,3	Heure des pics 3,0 h > 1,5
Forme 1 h 3,5 σ ≤ 3,5	Forme 2 h 3,1 σ ≤ 3,4	Pire écart 1 h 12,5 % ≤ 38,0	Verdict rejetée	Pointe jour. P95 5 394 / 6 613 W

