

0151GBO, froid, avril (depuis 2025-09-17)
20 journées, plaque 220 W + 220 W, 8 critères tenus sur 10

NRMSE 9,5 % ≤ 20,0	LDC 4,4 % ≤ 11,4	FFT 31,1 % > 20,0	Énergie +0,2 % ≤ 11,5	Pointe −3,9 % ≤ 16,8
Fact. de charge 2,3 % ≤ 10,0	CORR_h 3,9 % ≤ 10,0	TVD_h 5,5 % ≤ 12,5	EXT_prof 20,4 % ≤ 27,7	Heure des pics 3,0 h > 1,5
Forme 1 h 2,7 σ ≤ 3,9	Forme 2 h 2,0 σ ≤ 3,5	Pire écart 1 h 19,7 % ≤ 57,0	Verdict non vérifiable	Pointe jour. P95 368 / 379 W

