

0151GBO, froid, mai (depuis 2025-09-17)
20 journées, plaque 220 W + 220 W, 10 critères tenus sur 10

NRMSE 8,4 % ≤ 20,0	LDC 4,7 % ≤ 20,0	FFT 20,0 % ≤ 20,0	Énergie −0,8 % ≤ 20,0	Pointe −7,4 % ≤ 20,0
Fact. de charge 3,3 % ≤ 10,0	CORR_h 3,4 % ≤ 10,0	TVD_h 6,2 % ≤ 14,2	EXT_prof 11,9 % ≤ 41,5	Heure des pics 0,2 h ≤ 1,0
Forme 1 h 2,2 σ ≤ 3,0	Forme 2 h 2,6 σ ≤ 3,0	Pire écart 1 h 12,2 % ≤ 49,1	Verdict non vérifiable	Pointe jour. P95 325 / 367 W

