

0151GBO, froid, mars (depuis 2025-09-17)
22 journées, plaque 220 W + 220 W, 9 critères tenus sur 10

NRMSE 10,2 % ≤ 16,0	LDC 6,7 % ≤ 10,5	FFT 16,9 % ≤ 20,0	Énergie +2,8 % ≤ 10,0	Pointe −0,4 % ≤ 10,0
Fact. de charge 2,5 % ≤ 10,0	CORR_h 4,1 % ≤ 10,0	TVD_h 2,1 % ≤ 10,0	EXT_prof 9,4 % ≤ 29,6	Heure des pics 3,0 h > 2,0
Forme 1 h 3,3 σ ≤ 3,5	Forme 2 h 3,1 σ ≤ 3,3	Pire écart 1 h 20,2 % ≤ 39,0	Verdict rejetée	Pointe jour. P95 440 / 410 W

